



TOWN OF POUND RIDGE VILLAGE GREEN PROJECT

ADDENDUM #3

September 9, 2021

The following questions were received after the publication of Addendum #2 on September 3, 2021 .  
Our answers are in bold below each question.

1. Regarding bid item # 4 – Concrete Sidewalk Installation. Please highlight on the plans where concrete sidewalk is to be installed as we aren't seeing this on the plans.  
**The sidewalk labeled on the existing and proposed sheets shown to the righthand side of the plan leading from the entrance to the event stage shall be bluestone.**
2. For the bid items that have blank quantities, are we expected to provide these quantities, or can we bid them as a lump sum?  
**Bid Form Page C-3 has been revised and a copy is attached.**
3. Please confirm if the garden drain structure was removed from this project as the detail is no longer on the plans.  
**The garden drain structure was removed from the project plan. Drainage is provided via the perforated pipe.**
4. Please advise what we need to include for the Plaza Kiosk bid item. If we are to provide the kiosk, we'll need more information on the preferred style.  
**The Plaza Kiosk itself is not included, although provisions for the installation of power and internet for the kiosk should be included in the bid item. These include the conduits shown and the cost shall be included in Bid Item #14.**
5. We don't see a detail for the handrailing. Just the privacy fence. Please provide a detail for the handrailing.  
**The detail for the handrailing has been added and is shown on the Construction Detail Sheet D-1.**
6. For bid item #12-Unified Bluestone Curbing. Please clarify on what that is. We haven't seen anything on the plans or specs regarding that item.  
**Curbing refers to the granite curbing edging along the entrance to the walkway. The detail for curbing is shown on Construction Detail Sheet D-1 and is labeled Granite Planter Wall. The curbing is labeled on Layout Plan Sheet LP-1 shown near the entrance to the site to the east.**
7. A revised Plan Set dated 9.9.21 is attached.

Pitingaro & Doetsch Consulting Engineers, PC

  
Jason Pitingaro, PE  
President

G:\Shared Drives\Engineering\Pound Ridge\217803 - Village Green\01 - Admin\Addendum #3\PR Village Green Addendum #3.Docx