



Clean Energy Communities Energy Study

Prepared for:

Town of Pound Ridge - Town House
179 Westchester Ave.
Pound Ridge, NY 10576

Audit No: CEC204647-1-M

Submitted by:

L&S Energy Services
58 Clifton Country Road, Suite 203
Clifton Park, NY 12065

Date: 6/28/2023

For questions regarding this report, please contact cec@nyserdera.ny.gov.

We hope the findings of this report will assist you in making decisions about energy efficiency improvements in your facility. Thank you for your participation in this program.

NOTICE

This report was prepared pursuant to the Flexible Technical Assistance Program (Hereinafter "FlexTech") administered by the New York State Energy Research and Development Authority (hereinafter "NYSERDA"). The opinions expressed in this report do not necessarily reflect those of NYSEDA or the State of New York, and reference to any specific product, service, process, or method does not constitute an implied or expressed recommendation or endorsement of it by NYSEDA or the State of New York. Further, NYSEDA and the State of New York make no warranties or representations, expressed or implied, as to the fitness for a particular purpose or merchantability of any product, apparatus, or service, or the usefulness, completeness, or accuracy of any processes, methods, energy savings, or other information contained, described, disclosed, or referred to in this report. NYSEDA and the State of New York make no representation that the use of any product, apparatus, process, method, or other information will not infringe privately-owned rights and will assume no responsibility for any loss, injury, or damage resulting from, or occurring in connection with, the use of information contained, described, disclosed, or referred to in this report.

State of New York

Kathy Hochul, Governor

New York State Energy Research and Development Authority



Consultant Disclaimer

The opinions expressed in this report do not necessarily reflect those of L&S Energy Services, C.J. Brown Energy P.C., The Daylight Savings Company, or Taitem Engineering P.C. (the Consultants), and reference to any specific product, service, process, or method does not constitute an implied or expressed recommendation or endorsement of it by the Consultants. Further, the Consultants make no warranties or representations, expressed or implied, as to the fitness for a particular purpose or merchantability of any product, apparatus, or service, or the usefulness, completeness, or accuracy of any processes, methods, energy savings, or other information contained, described, disclosed, or referred to in this report. The Consultants make no representation that the use of any product, apparatus, process, method, or other information will not infringe privately-owned rights and will assume no responsibility for any loss, injury, or damage resulting from, or occurring in connection with, the use of information contained, described, disclosed, or referred to in this report.

This report was prepared by:

L & S Energy

58 Clifton Country Road, Suite 203

Clifton Park, NY 12065

(518) 383-9405

Table of Contents

Executive Summary	1
Present Energy Use and Cost	2
Benchmarking Your Building.....	3
Project Summary Table	4
Note on Energy Project Implementation Costs	5
Greenhouse Gas Reductions for the Recommended Measures.....	6
Energy Efficiency Measure Descriptions	7
EEM-1 Interior Lighting Retrofit	7
EEM-2 Exterior Lighting Retrofit	8
EEM-3 Improve Temperature Control	9
EEM-4 Insulate Building Envelope.....	10
EEM-5 Install Double Glazing	11
EEM-6 Install Duct Insulation	12
EEM-7 Insulate Heating And Domestic Hot Water Pipes	13
EEM-8 Install Motor Controls.....	14
EEM-9 Replace Condensing Units.....	15
EEM-10 Install A More Efficient Boiler.....	16
Building Electrification Measures	17
BE-1 Install A Tankless Water Heater.....	18
BE-2 Install Clean Heating System - Air Source Heat Pump	19
BE-3 Install Clean Heating System - Ground Source Heat Pump.....	20
Existing Conditions	21
Lighting Systems.....	21
Heating Ventilating and Air Conditioning Systems.....	21
Water Heating System	22
Other Energy-using Systems.....	22
Appendix A	23
Equipment Inventory.....	23
Appendix B.....	25
Energy Use and Cost Summary	25
Utility Bill Data.....	25
Appendix C	28
EEM Calculations.....	28
Appendix D	42
Assumptions/Data Used to Develop Energy and Dollar Savings Figures.....	42
Appendix E.....	45
Clean Heating and Cooling Technology Overview.....	45
Appendix F	49

Energy Savings Summaries49

Executive Summary

This study was performed to understand how your facility is currently using energy and identify ways to reduce energy use and operating expenses.

Specific areas of concern that were identified by the owner for evaluation include lighting and envelope.

The following energy efficiency measures (EEMs) and observations to reduce energy use were identified during the site visit:

- Interior and Exterior Lighting Retrofits – Install LEDs and occupancy controls.
- Improve Temperature Controls – Install Wi-Fi Thermostats and implement deep setback schedules.
- Insulate Building Envelope – Replace and add attic, wall, and basement insulation.
- Install Double Glazing – Replace single pane windows with double pane units and reduce infiltration.
- Install Duct Insulation – The AHU ducts do not have insulation throughout the attic.
- Insulate Heating & Domestic Hot Water Pipes – There are bare pipes in the basement.
- Install Motor Controls – Add controls to turn off HVAC distribution pumps.
- Replace Condensing Units – The AC units are very old and need to be replaced.
- Install a More Efficient Boiler – Replace the existing boiler with a high efficiency condensing unit.
- Install a Tankless Water Heater – Separate the DHW system from the boiler plant.
- Air Source Heat Pumps – Replace the AC and Boiler plant with an Air Source Heat Pump system.
- Ground Source Heat Pumps - Replace the AC and Boiler plant with a Ground Source Heat Pump system.

These Energy Efficiency Measures are summarized in the Project Summary Table below and discussed in more detail in the Energy Efficiency Measures section of this report.

Present Energy Use and Cost

The energy use for your facility has been compiled to calculate the Energy Cost Index and the Energy Use Intensity.


- The Energy Cost Index (ECI) is the total cost of energy divided by the conditioned floor area and is shown as dollars per square foot per year.
- The Energy Use Intensity (EUI) is the total heat content of energy divided by the conditioned floor area and is shown in units of one thousand Btus (kBtu) per square foot per year.

Energy Cost Index


Electricity	\$ 7,882	\$ 1.23	\$/sq.ft./year
Oil - No. 2	\$ 8,941	\$ 1.39	\$/sq.ft./year
Total Cost	\$ 16,822	\$ 2.62	\$/sq.ft./year

Energy Use Intensity

Electricity	195 mmBtu	30.4	kBtu/sq.ft./year
Oil - No. 2	358 mmBtu	55.8	kBtu/sq.ft./year
Total Energy Use	553 mmBtu	86.2	kBtu/sq.ft./year



Energy Cost Index \$ 2.62 /sf/yr.



Energy Use Intensity 86.2 kBtu/sf/yr.

Benchmarking Your Building

The EPA's ENERGY STAR Portfolio Manager website allows you to upload energy use information and compare your energy use to that of other buildings of similar use. Portfolio Manager generates a benchmark score that indicates your performance. A benchmark score of 50 indicates average performance while a score of 75 or higher would earn the Energy Star designation. You can use the website to track your energy use over time and document the success of your energy conservation efforts.

You can find the Portfolio Manager at:

<https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/use-portfolio-manager>

Project Summary Table

Energy Efficiency Measures				\$ Savings & Cost		
EEM #	Measure Status	EEM Description	Reduction in Greenhouse Gas Emissions (Lbs. CO2e/Year)	Total Annual Savings	Install Costs	Simple Payback (years)
EEM-1	R	Interior Lighting Retrofit	5,655	\$ 1,014	\$ 5,518	5.4
EEM-2	R	Exterior Lighting Retrofit	41	\$ 4	\$ 42	10.6
EEM-3	R	Improve Temperature Control	9,162	\$ 1,354	\$ 2,700	2.0
EEM-4	RS	Insulate Building Envelope	30,690	\$ 4,673	\$ 52,918	11.3
EEM-5	RS	Install Double Glazing	13,979	\$ 1,935	\$ 36,774	19.0
EEM-6	NR	Install Duct Insulation	221	\$ 22	\$ 1,200	55.3
EEM-7	R	Insulate Heating And Domestic Hot Water Pipes	868	\$ 133	\$ 349	2.6
EEM-8	R	Install Motor Controls	1,765	\$ 173	\$ 300	1.7
EEM-9	NR	Replace Condensing Units	2,990	\$ 463	\$ 19,000	41.0
EEM-10	ME	Install A More Efficient Boiler	12,387	\$ 1,897	\$ 15,000	7.9
Total of Recommended Measures:			17,491	\$ 2,678	\$ 8,909	3.3

Measure Status Explanation:

(I) - Implemented: Measure has been installed

(R) - Recommended: Energy saved with a reasonable payback (within measure life)

(NR) - Not Recommended: When payback exceeds measure life and equipment is not at end of life

(RME) - Recommended Mutually Exclusive: Energy is saved and recommended over other options for a particular measure

(ME) - Mutually Exclusive: Non-recommended option(s) to a Recommended Mutually Exclusive (RME) measure

(RNE) - Recommended Non-Energy: Recommended based on other, non-energy factors such as comfort, water savings or equipment at end of life

(RS) - Recommended for Further Study: For measures that require analysis beyond the scope of this program.

(BE) – Building Electrification: Measures that should be considered based on greenhouse gas reductions, eliminating on-site use of fossil fuels, or other sustainability factors

Building Electrification Measures				\$ Savings & Cost				
EEM #	Measure Status	Building Electrification Measure Descriptions	Reduction in Greenhouse Gas Emissions (Lbs. CO2e/Year)	Total Annual Savings	Install Costs	Simple Payback (years)	Estimated Incentives	Simple Payback after incentives
BE-1	R	Install A Tankless Water Heater	3,725	\$ 590	\$ 1,000	1.7	\$ 2,809	1.7
BE-2	RME	Install Clean Heating System - Air Source Heat Pump	20,812	\$ 4,194	\$ 47,160	11.2	\$ 17,760	7.0
BE-3	ME	Install Clean Heating System - Ground Source Heat Pump	28,128	\$ 5,145	\$ 145,730	28.3	\$ 18,422	24.7
Total of Recommended Measures:			24,537	\$ 4,784	\$ 48,160	10.1	\$ 20,569	5.8

Simple Payback Period is the length of time it will take to recover the initial capital investment from the energy savings of the new equipment. The Simple Payback Period is calculated by dividing the initial installed cost by the annual energy cost savings. For example, an energy-saving measure that costs \$5,000 and saves \$2,500 per year has a Simple Payback Period of \$5,000 divided by \$2,500 or 2 years.

Note on Energy Project Implementation Costs

The "Project Costs" shown in this report for each Energy Efficiency Measure represent an initial estimate of the implementation cost. Unless otherwise noted in the Energy Efficiency Measure description, these costs reflect a preliminary estimate of material and labor. There may be other variables associated with your specific project that will impact the true project costs that the study may not capture. Other external factors that may impact true project costs and payback include material availability, vendor scheduling, access within the facility, general inflation, available measure incentives, and other unknown factors and conditions. For measures which significantly impact your building's usage, it is also important to determine any potential utility rate and/or tariff changes, those of which are beyond the scope of this report. We recommend that you seek several quotes from qualified vendors prior to implementation.

Greenhouse Gas Reductions for the Recommended Measures

Reducing your energy use will reduce the release of greenhouse gases associated with the use of fossil fuels and the production of electricity. If the measures recommended in this report are implemented, the following reductions of greenhouse gases can be expected:

Electricity	(19,466)	kWh =	(22,580)	pounds CO2 equivalent
Oil - No. 2	2,874	gal. =	64,608	pounds CO2 equivalent
			<hr/>	
			42,028	pounds CO2 equivalent
			33.7%	reduction

Emissions factors are used to translate the energy savings data from energy efficiency and renewable generation projects into annual GHG emissions reduction values. NYSERDA uses emission factors derived from U.S. Environmental Protection Agency (EPA) emission coefficients to calculate emissions from onsite fuel. The CO₂e values represent aggregate CO₂, CH₄, and N₂O emissions.

Energy Efficiency Measure Descriptions

EEM-1 Interior Lighting Retrofit

Electric Savings:	\$ 1,376	6,914 kWh per year 4.5 kW demand
Fuel Savings:	(\$ 362)	(14.5) MMBtu fuel per year Oil - No. 2
Total Annual Savings:	\$ 1,014	
Project Cost:	\$ 5,518	
Simple Payback:	5.4	years

Introduction:

The existing lights consist primarily of fluorescent T-8 tubes and incandescent lamps in wall or ceiling sconces. Many of the spaces have lights that are left on when nobody is in the room. As such occupancy sensors should be installed.

Both the appendix and calculations show the specific locations, quantities, and fixture types for replacement.

Recommendation:

Replace the lamps with LED equivalents. The fluorescent fixtures could also be replaced, but a cheaper option exists by cutting out the ballast and direct wiring in LED self-driving T-8 tubes.

Consider calling the NYSEG direct installation program opportunity if the Town is too busy or does not have the resources to install, replace, or relamp the new lights and occupancy sensors as directed in the calculations.

EEM-2 Exterior Lighting Retrofit

Electric Savings:	\$ 4	35 kWh per year 0.0 kW demand
Fuel Savings:	\$ 0	0.0 MMBtu fuel per year
Total Annual Savings:	\$ 4	
Project Cost:	\$ 42	
Simple Payback:	10.6	year s

Introduction:

The motion sensor fixtures on the side of the building have incandescent lamps.

Recommendation:

Replace the lamps with LED equivalents.

EEM-3 Improve Temperature Control

Electric Savings:	\$ 88	773 kWh per year 0.0 kW demand
Fuel Savings:	\$ 1,266	50.7 MMBtu fuel per year Oil - No. 2
Total Annual Savings:	\$ 1,354	
Project Cost:	\$ 2,700	
Simple Payback:	2.0	years

Introduction:

Proper temperature control is important in order to minimize energy costs. Maintaining space temperatures within a reasonable range during occupied periods and reliably reducing the amount of heating and cooling energy during unoccupied periods should be the goal for your temperature control system.

Facilities that are occupied only on weekdays can maintain a lower space temperature setpoint on weekends. Programmable thermostats are available that permit full 7-day schedules to be defined. 5-2 or 5-1-1 thermostats use the same schedule for all weekdays and provide one or two schedules for weekend days.

Recommendation:

There are multiple types of thermostats in each of the spaces. While most are programmable, staff overwrite the programs and keep the zones at a constant temperature even when they leave for the night.

This measure recommends installing (9 total) Wi-Fi enabled thermostats so that the facility manager can control each zone and maintain the space temperatures when occupied. The calculation provides an example of a 4-degree setback at night, but the mechanical contractor should provide a detailed quote and plan to deepen the setbacks as much as possible to save energy and maintain comfort during occupied times.

EEM-4 Insulate Building Envelope

Electric Savings:	\$ 49	432 kWh per year 0.0 kW demand
Fuel Savings:	\$ 4,623	185.3 MMBtu fuel per year Oil - No. 2
Total Annual Savings:	\$ 4,673	
Project Cost:	\$ 52,918	
Simple Payback:	11.3	years

Introduction:

Heat moves from areas of high temperature to areas of low temperature. As the temperature difference between a heated and an unheated space becomes greater, so does the rate of heat transfer. Insulation reduces the rate of heat transfer by filling the space with material that is less conductive than what is currently there. The effectiveness of insulation is measured by R-value, which is the resistance to heat transfer. As the R-value increases, the rate at which heat is transferred decreases.

Insulation can be installed in enclosed spaces, such as wall cavities, cathedral ceiling cavities, and floored attic cavities. It can also be installed in unfloored attics, which can accommodate greater thickness resulting in higher R-value. When insulation is combined with air sealing, convective air currents that circulate air within cavities and through insulation are reduced, which increases the effective R-value of the insulation.

Recommendation:

This measure provides an example of increasing the R-Value in the roof from an estimated R-10 to R-38, and the walls from R-3.7 to R-10. The measure is recommended for further study due to many reasons and costs should be ascertained by competent contractors who specialize in both removal and remediation of old insulation and sealing other penetrations. Costs for insulating the basement ceiling between the joists should be included as well as different scenarios for the walls, because they may not be able to be insulated adequately with blown in insulation, where an exterior insulating finishing system might be the best opportunity to maximize the R-Value.

EEM-5 Install Double Glazing

Electric Savings:	(\$ 206)	0 kWh per year 0.0 kW demand
Fuel Savings:	\$ 2,141	85.8 MMBtu fuel per year Oil - No. 2
Total Annual Savings:	\$ 1,935	
Project Cost:	\$ 36,774	
Simple Payback:	19.0	years

Introduction:

Single pane wooden or metal frame windows can be very inefficient. Heat loss due to conduction through single pane windows can be very high. New windows utilize two panes of glass instead of one. Glass performance is measured in two ways Solar Heat Gain Coefficient (SHGC) or Visible Transmittance (VT). SHGC is the amount of solar gain transmitted through a window into the building. VT refers to the amount of visible light that moves through the glass from exterior to interior. These two factors can be altered for a higher performing window by adding Low-E coatings and spacers with gas. The overall thermal performance of windows is generally assigned a u-value. This measurement considers all parts of a window. These parts include the frame, sash, and glass. The installation of windows with double glazing will reduce infiltration and conduction losses.

Recommendation:

Install new double-glazed windows with low-e coatings. Be sure that windows are fully caulked on the exterior and interior where they meet the existing building structure. The EPA and DOE have developed stringent standards for windows. Windows that meet these standards can earn the Energy Star Label. Replacement windows should bear the Energy Star label.

This measure provides an estimate for replacing the single pane windows with new double pane units that prevent air leakage through the frames, which was based on 10% of the overall wall area. Savings for increasing the R-Value from 0.9 to 3 and reducing the infiltration by half. Windows are prohibitively expensive, due mainly to custom sizes and labor. This measure is recommended for further study like the previous measure for the same reasons of cost creep due potential issues with an older building. Though, if the same contractor is able to replace and seal the windows, there could be a reduction in costs through scale.

EEM-6 Install Duct Insulation

Electric Savings:	\$ 22	190 kWh per year 0.0 kW demand
Fuel Savings:	\$ 0	0.0 MMBtu fuel per year
Total Annual Savings:	\$ 22	
Project Cost:	\$ 1,200	
Simple Payback:	55.3	years

Introduction:

Sheet metal ducts located in basement, attic or other unconditioned spaces lose energy and reduce overall system efficiency. The heating and cooling systems must operate longer to compensate for this energy loss. Adding insulation to supply and return air ducts will reduce this energy loss and improve system efficiency.

Ducts in conditioned spaces experience minimal conductive losses and gains since they are exposed to indoor spaces that must be conditioned in any event. However, these ducts may also require some insulation to prevent condensation on duct walls and to ensure that conditioned air is delivered at the desired temperature.

Recommendation:

This measure provides an example of the potential savings for insulating the attic AC ducts. Due to lower hours of use, this measure does not have a good payback relative to costs and is not recommended.

This measure is impacted by other AC and Building Electrification retrofit measures, which may require replacement of the existing distribution systems. It may also be a good idea to implement EEM-4 prior to installing new AC equipment).

Further, staff indicated that the zone controllers were not working, which should be ascertained by the mechanical contractor. The costs of fixing the existing system should be compared against the costs of replacement.

EEM-7 Insulate Heating And Domestic Hot Water Pipes

Electric Savings:	\$ 0	0 kWh per year 0.0 kW demand
Fuel Savings:	\$ 133	5.3 MMBtu fuel per year Oil - No. 2
Total Annual Savings:	\$ 133	
Project Cost:	\$ 349	
Simple Payback:	2.6	years

Introduction:

Heat is distributed through the building by pipes containing hot water or steam. Heating distribution system pipes lose heat to the surrounding space. If the heat is lost to an area that does not require heating, the drop in system efficiency can be significant. Un-insulated pipes in conditioned space may also overheat the space, wasting energy and causing comfort problems. All heating distribution system pipes located in unconditioned space should be insulated.

Recommendation:

The heating hot water distribution pipe from the boiler to the pumps is not insulated fully. The domestic hot water pipes from the submerged coil are not insulated at all, and they are always hot.

Install 2 in. insulation on (10 ft.) of 2 in. Dull Copper Hot Water pipe, 0.5 in. insulation on (25 ft.) of 0.5 in. Dull Copper DHW pipe and 1 in. insulation on (10 ft.) of 1 in. Dull Copper DHW pipe.

EEM-8 Install Motor Controls

Electric Savings:	\$ 173	1,521 kWh per year 0.0 kW demand
Fuel Savings:	\$ 0	0.0 MMBtu fuel per year
Total Annual Savings:	\$ 173	
Project Cost:	\$ 300	
Simple Payback:	1.7	years

Introduction:

The heating hot water/cold water pumps cycle monthly. However, one always operates to circulate the cold water or the hot water at all times even if the thermostats are not calling for heat from the radiators or cold air from the AHUs.

These motors will reach the end of their useful life faster. The pipes will lose temperature to the space while circulating water needlessly during unoccupied times causing the boiler or condensing units to engage more often during short cycles. This causes the units to operate inefficiently at low loads.

Recommendation:

The mechanical contractor should identify a control mechanism such as an aquastat to disengage the pump when the loop or thermostat temperatures are satisfied.

This calculation only estimates savings for reducing the running time of the motor by an estimated 50%. There are additional savings for interactive heating and cooling that can be identified for further study.

EEM-9 Replace Condensing Units

Electric Savings:	\$ 463	2,578 kWh per year 3.1 kW demand
Fuel Savings:	\$ 0	0.0 MMBtu fuel per year
Total Annual Savings:	\$ 463	
Project Cost:	\$ 19,000	
Simple Payback:	41.0	years

Introduction:

Air conditioning units that are over 15 years old may use reciprocating compressors and obsolete refrigerants. Current models use reliable scroll compressors and modern refrigerants to meet today's more stringent efficiency requirements. Replacement models are rated with an Energy Efficiency Ratio, commonly called EER. The higher the EER, the more efficient the unit. SEER is the Seasonal Energy Efficiency Ratio, which indicates the average EER over the course of a cooling season. The SEER will be higher than the EER for a given piece of equipment, so be sure to compare products using the same measurements.

The energy savings of a new air conditioning system is often not enough to warrant the purchase of a new unit. However, if the air conditioner requires repair or needs replacement for another reason, the highest EER rated equipment should be purchased.

Recommendation:

The original condensing units are at the end of their service life and need to be replaced. Due to the low hours of use, and the high cost of replacement, this measure does not pay back and is not recommended. They are also at the end of their useful lives, so the costs to replace should be used to compare against high efficiency building electrification measures that will be described in subsequent measures.

EEM-10 Install A More Efficient Boiler

Electric Savings:	\$ 0	0 kWh per year 0.0 kW demand
Fuel Savings:	\$ 1,897	76.0 MMBtu fuel per year Oil - No. 2
Total Annual Savings:	\$ 1,897	
Project Cost:	\$ 15,000	
Simple Payback:	7.9	years

Introduction:

Boiler efficiency is determined by the efficiency of the boiler burner and heat exchanger, jacket heat losses, flue losses, and boiler sizing relative to the heating load. Boilers that are oversized spend more time in standby mode, increasing the impact of high off-cycle flue losses. These types of boilers perform at overall efficiencies significantly lower than their nominal thermal efficiency (Et), which is measured at a steady state of boiler operation.

Non-condensing boilers are limited to thermal efficiencies up to ~85% Et if equipped with power burners and low-mass heat exchangers; 80% Et boilers are more common. Condensing boilers are designed to cool flue gases to the point where water vapor produced in the combustion process condenses. The thermal efficiency of a condensing boiler depends on the entering water temperature, with lower temperatures yielding higher efficiency. Condensing boilers can achieve thermal efficiencies between 88% and 98%.

Recommendation:

This measure simply provides an analysis for installing a new oil fired condensing boiler. Though, it may be difficult to procure one since most condensing units have gas/propane fired burners. In addition, the boiler will not have a domestic hot water coil, so a new domestic hot water maker will need to be purchased (note that there are many options for high efficiency combi-boilers, but they also require gas/propane). Hot water heating via perimeter radiators is not the most effective way to heat this facility since the walls are not insulated. Most facilities cannot overcome this deficiency, but ducts provide cold air via water coils in the AHUs. There could be a way to retrofit the air distribution system to provide hot air via a gas fired condensing furnace.

NYS has goals to remove fossil fuel heating from buildings, and the boiler is reaching the end of its useful life in a few years. Now is the time to have a comprehensive plan to upgrade the building infrastructure before a failure necessitates an emergency boiler replacement that will last another 15 years. The mechanical contractor should provide quotes for both the replace-in-kind as well as consideration of a gas furnace, but both should be used to compare against the subsequent building electrification measures. As such, this measure is considered mutually exclusive despite a potential good payback.

Building Electrification Measures

The following measures evaluate the impact of replacing your existing fossil-fuel heating systems with clean heating and cooling systems powered by electricity. For space heating, air source heat pumps and ground source heat pumps are available in various system types to provide both heating and cooling to your building.

Fossil fuel-fired water heaters may also be replaced with heat pump water heaters to further reduce your use of fossil fuels.

When combined with renewable electricity, heat pump systems can eliminate the use of fossil fuels in your building.

See Appendix E - Benefits Of Clean Heating and Cooling (CHC) Technologies for more information on these system types.

BE-1 Install A Tankless Water Heater

Electric Savings:	(\$ 567)	(3,301) kWh per year (1.5) kW demand
Fuel Savings:	\$ 1,157	46.4 MMBtu fuel per year Oil - No. 2
Total Annual Savings:	\$ 590	
Project Cost:	\$ 1,000	
Simple Payback:	1.7	years

Introduction:

There is a submerged coil in the boiler that provides hot water on demand. During the summer, the demand on the boiler is so low that the unit operates inefficiently to make domestic hot water.

This calculation estimates that the current oil usage is 14% for domestic hot water using utility bill extrapolation. This is quite high for simply hand and dishwashing.

Recommendation:

Install a tankless on demand unit that is electric that is size to serve the hot water loads in the facility.

BE-2 Install Clean Heating System - Air Source Heat Pump

Electric Savings:	(\$ 3,508)	(25,408) kWh per year 2.2 kW demand
Fuel Savings:	\$ 7,702	308.7 MMBtu fuel per year Oil - No. 2
Total Annual Savings:	\$ 4,194	
Project Cost:	\$ 47,160	
Simple Payback:	11.2 years	7.0 years after incentives

Introduction:

Air source heat pumps (ASHP) provide both heating and cooling using electricity to exchange energy with the outdoor air. Existing buildings may be retrofitted with various heat pump technologies to reduce or eliminate their dependence on fossil fuels for space heating. System options range from centrally-ducted cold climate air source heat pumps and mini-split heat pumps to large variable refrigerant flow systems having multiple indoor units supported by each outdoor unit.

At very cold outdoor air conditions, air source heat pumps may require supplemental heat to meet your building's heating load. Supplemental heat may be in the form of electric resistance heat or your existing fossil-fueled heating system, if it remains in service. The extent to which an ASHP system reduces your fossil fuel use will depend on the exact design and control of your new system.

Recommendation:

Replace your oil - no. 2 heating system with a central ducted air source heat pump system serving the entire building. The system type is: Central Ducted ASHP with Integrated/Modulating controls sized to 100% of the building heating load.

The heat pumps are assumed to be rated at 13.05 EER full load cooling, 15 SEER. The heat pumps are assumed to be rated at 10 HSPF for heating, which may be adjusted to 2.52 COP. Be sure to specify heat pumps that meet NEEP requirements (Northeast Energy Efficiency Partnerships). See https://ashp.neep.org/#!/product_list/ for current models that meet these requirements.

They should be rated for cold climates (needing a larger size to accommodate the reduction in capacity during cold temperatures) so that the boiler plant can be removed. This measure has the best payback for heating and cooling the facility with heat pumps and is considered recommended, mutually exclusive. However, this is based on probable costs without incentives. The subsequent ground source heat pump has better utility incentives at this time and should be also evaluated.

BE-3 Install Clean Heating System - Ground Source Heat Pump

Electric Savings:	(\$ 1,922)	(15,531) kWh per year 3.4 kW demand
Fuel Savings:	\$ 7,067	283.3 MMBtu fuel per year Oil - No. 2
Total Annual Savings:	\$ 5,145	
Project Cost:	\$ 145,730	
Simple Payback:	28.3 years	24.7 years after incentives

Introduction:

Smaller buildings can take advantage of water-to-air ground source heat pump technology by replacing furnaces and other ducted systems with heat pumps having either open or closed loop ground heat exchangers. Closed loop ground heat exchangers that are properly sized provide water between 32° and 77° for heat pumps to draw heat from or reject heat to. Open loop systems see water temperatures of ~50° throughout the year. This allows heat pumps to operate at higher efficiency than air-source heat pumps that must draw from more extreme outdoor air temperatures.

The heat pumps in this type of system each have a loop pump. The building may have multiple heat pumps, but every heat pump must have a dedicated ground source heat exchanger. The heat pumps should have two-stage or variable capacity compressors for the highest efficiency. The loop pump may be constant speed, but two-speed or variable speed pumps offer higher efficiency and are preferred.

Recommendation:

Consider replacing your present heating system with a clean heating and cooling system using ground source heat pumps.

Install a closed loop heat pump system with variable-speed compressors and variable pumping. The heat pumps are assumed to be rated at 17 EER full load cooling, 22 EER part load. The heat pumps are assumed to be rated at 3.6 COP full load heating, 4.1 COP part load.

This is the most efficient option; however, it has the highest cost component without incentives. NYSEG has a very good incentive opportunity for GSHPs relative to ASHP and the Federal Inflation Recovery Act has likely a 40% tax credit (that can be directly paid to the municipality) available, making this option likely on par with the previous measure. Consult a competent contractor to identify the possibility of this option in addition to the ASHP that are recommended based on this study.

Existing Conditions

This site is a Town Hall with multiple departments. Originally, this building was constructed in 1850 as a private residence. There was an addition in 1988 that built out the rear and expanded the second story. Overall, the facility is 6,420 ft² with 3,658 ft² on the first floor and 2,762 ft² on the second floor. There are at least 20 staff in the office daily with many more people coming in person to meet with the staff about their buildings, taxes, or have meetings at the court, or for their committees and non-profits as this building is one of the only places in town to gather in a public forum. The typical office hours are 9-5 M-F, but oftentimes meeting spaces are open as late as midnight.

There is a small basement and crawlspace under the original part of the building. The basement has a slab floor and stone walls, while the crawlspace has a dirt floor. The building is wood frame, with 2"x4" boards in the original building and 2"x6" boards in the addition. There is no insulation between the wall frames in the original building, but there is some insulation in the addition. The exterior siding is wood cladding, and the interior is drywall. The main hipped roof has minimal, aged insulation, boarded up on the underside of the roof deck above the attic. A smaller hipped roof has an attic crawlspace, which has vermiculite, or similar older insulation on the attic floor between the joists.

The original building has exclusively single pane windows. About half the windows are double hung, while the others are fixed or can open by handle. The addition has double pane glass and double hung windows. All have wood frames. There are also several doors to the facility, and they are all solid wood with good weather stripping and/or seals.

Lighting Systems

Lighting is primarily 4' T-8 fluorescent surface mount fixtures. There are also a mixture of candelabra type chandelier or wall sconce incandescent fixtures as well as incandescent ceiling surface mount lamps. The recessed lamps are either incandescent, or LED. Some desk lamps are CFL. All lights are controlled via switches, and many are left operating all day (and evening) when the space is unoccupied until the last person (or security) in the office turns them off at night.

Exterior fixtures consist of LED wall packs that operate at night with photocells, and two CFL wall sconces on a switch at night. The side doors have 100W incandescent lights on motion sensors.

Heating Ventilating and Air Conditioning Systems

Heating is provided by a hot water cast iron boiler, fired by oil. The boiler is a Peerless, model EC-04-WPCL, manufactured in 2013. It has a firing rate of 1.75 gallons per hour, and 245 Mbh, with an output of 215 Mbh, per specifications found online. The DOE energy rating sticker is 84.5% while the specifications suggest an AFUE of 86.8%. The boiler uses two, 1/2 hp pumps (that cycle monthly) to circulate hot water to radiator/console units along the perimeter of the facility. Most of the pipes in the boiler room are insulated.

Cooling is provided by two condensing units that cool water pipes instead of refrigerant lines. The condensing units are Trane, model TTD760B1000A2 units from 1990. The outdoor fan motor has a 1/4 capacity. The water loop ties into the (same heating) pumps in the basement which circulate the cold water to two air handling units (AHUs) in the attic space that distribute cold air to ducts in the wall. The AHUs are Magic Aire 36-BHW-4 units with 1/3 hp units with a 3-ton capacity. The air handlers serve ducted distribution in the walls along the first and second floors. The ducts in the attic are not insulated.

The addition has a separate heating and cooling distribution system located in the attic that was not accessed during the walkthrough. The AHU has a hot water coil that uses the existing boiler, and a refrigerant coil that is served by a Lennox condensing unit, model HS18-461-4P, manufactured in 1997.

There are various controls serving the zones. The addition has old Robert Shaw analog units, and Town Supervisor has a new Honeywell touchscreen home unit. The rest of the units are Honeywell digital 5-1-1 thermostats. The controls, however, are not used for the most part. Staff overwrite the controls and hold the temperature. They claim that heating and cooling do not work well in parts of the building, and therefore the control setpoints are held around 70-74 °F in heating and cooling modes.

Staff also claim that the zone dampers for the cooling system do not work. There is also likely an imbalance in the building. Another issue is that the size of the systems is unable to serve the spaces in peak temperatures due to leaky windows and uninsulated or poorly insulated walls/windows.

The heating system is valved off from the main distribution during cooling season and vice versa. The circulator pump never turns off despite the controls not calling for heating or cooling.

The server room has a small window AC unit. It is a Perfect Aire unit with a 5,000 Btu/h capacity and an 11 CEER. The basement has an Electrolux dehumidifier with a 50 pint/day capacity that was manufactured in 2010.

Water Heating System

The boiler has a submerged coil in it for hot water needs and stays hot all year round. There is no storage tank and the 1/2" copper pipes are not insulated. The temperature was measured at 123 °F and the water is used for handwashing and dishwashing.

Other Energy-using Systems

This building has typical office equipment. Each space has multiple computers and printers. There is a security system, and two server cabinets. There is a small kitchen with a refrigerator, microwave, toaster, oven set, and a dishwasher.

See Appendix D for further details regarding the energy calculations performed for this study.

Appendix A

Equipment Inventory

Heating and Air Conditioning Equipment									
Unit Type	Qty	Make/Model	Heating kBtuh	Heating Eff.	Cooling Capacity	Units	EER	Serves/Location	Year
Cast Iron Boiler	1	Peerless EC-04-WPCL	245	84.50%				All Building/Basement	2013
Condensing Units	2	Trane TTD760B1000A2			3	tons	9.0	All Building/Ext. Rear	1990
Window AC	1	Perfect Aire 5PMC			0.42	tons	11.0	Server Room	2018
Split System AC	1	Lennox HS18-461-4P			3 1/2	tons	9.0	Addition/Ext. Rear	1997

Domestic Hot Water									
Unit Type	Qty	Make/Model	Capacity	Units	Fuel Type	Storage Capacity (gal.)	Eff.	Serves/Location	Year
Tankless	1	Peerless EC-04-WPCL	245	kBtu/h	Oil - No. 2	None	84.5%	Faucets/Basement	2013

Motors									
Unit Type	Qty	Make/Model	HP	Loading	Type	Hours/year	Eff.	Serves/Location	Year
Filtration Pump	1	Baldor Reliance	1/2					Domestic Water Tanks/Basement	
HHW/CHW Pump	1	Baldor Reliance	1/2					Radiators & AHUs/Basement	
HHW/CHW Pump	1	Magnetek	1/3					Radiators & AHUs/Basement	
Condenser Fan	2	Trane	1/4					Cooling/Exterior Rear	
AHU Fan	2	Magic Aire	1/3					Cooling/Attic	

Interior Lighting Fixtures											
Existing Fixtures						Recommended	Recommended Interior Lighting Efficiency Improvements				
Line #	Area	Qty	Present Lighting Type	Lamps /fixt	Watts /Fixt	Control Type	Measure Type	Qty	Proposed Lighting Type	Lamps /fixt	Watts /Fixt
1	Basement	6	4' 32w T8 Elec. bal.	2	59	No Change	Linear LED Bypass	6	4' LED T8 2000 lu. 14W	2	28
2	Basement	1	100 watt Incandescent	1	100	No Change	LED Relamp	1	A19 LED, 14W	1	14
3	Basement	1	A19 LED, 9W	1	9	No Change	No change	1	A19 LED, 9W	1	9
4	Bldg. Dept.	5	4' 32w T8 Elec. bal.	2	59	No Change	Linear LED Bypass	5	4' LED T8 2000 lu. 14W	2	28
5	Bldg. Dept. Vault	5	4' 32w T8 Elec. bal.	2	59	Remote Occ Sensor	Linear LED Bypass	5	4' LED T8 2000 lu. 14W	2	28
6	Records Room	2	4' 32w T8 Elec. bal.	2	59	Remote Occ Sensor	Linear LED Bypass	2	4' LED T8 2000 lu. 14W	2	28
7	Tax Office	4	4' 32w T8 Elec. bal.	2	59	No Change	Linear LED Bypass	4	4' LED T8 2000 lu. 14W	2	28
8	Rear Hallway	4	4' 32w T8 Elec. bal.	2	59	No Change	Linear LED Bypass	4	4' LED T8 2000 lu. 14W	2	28
9	Hallway	2	60 watt Incandescent	1	60	No Change	No change	2	A19 LED, 9W	1	9
10	Hallway	1	4' 32w T8 Elec. bal.	2	59	No Change	Linear LED Bypass	1	4' LED T8 2000 lu. 14W	2	28
11	Court Office	3	4' 32w T8 Elec. bal.	2	59	Remote Occ Sensor	Linear LED Bypass	3	4' LED T8 2000 lu. 14W	2	28
12	Kitchen	2	4' 32w T8 Elec. bal.	2	59	Remote Occ Sensor	Linear LED Bypass	2	4' LED T8 2000 lu. 14W	2	28
13	Side Hallway	3	75 watt Incandescent	1	75	No Change	LED Relamp	3	A19 LED, 9W	1	9
14	Dining Room	1	25 watt Incandescent	8	200	No Change	LED Relamp	1	A15 LED, 5W	8	40
15	Dining Room	8	PAR30 LED, 12W	1	12	No Change	No change	8	PAR30 LED, 12W	1	12
16	Dining Room	6	40 watt Incandescent	1	40	No Change	LED Relamp	6	A15 LED, 6W	1	6
17	Town Clerk	6	4' 32w T8 Elec. bal.	2	59	Remote Occ Sensor	Linear LED Bypass	6	4' LED T8 2000 lu. 14W	2	28
18	Clerk Office	3	4' 32w T8 Elec. bal.	2	59	No Change	Linear LED Bypass	3	4' LED T8 2000 lu. 14W	2	28
19	Reception	1	25 watt Incandescent	3	75	No Change	LED Relamp	1	A15 LED, 5W	3	15
20	Reception	2	40 watt Incandescent	1	40	No Change	LED Relamp	2	A15 LED, 6W	1	6
21	Courtroom	11	PAR30 LED, 12W	1	12	No Change	No change	11	PAR30 LED, 12W	1	12
22	Supervisor Office	3	100 watt Incandescent	1	100	No Change	LED Relamp	3	A19 LED, 14W	1	14
23	Supervisor Office	4	40 watt Incandescent	1	40	No Change	LED Relamp	4	A15 LED, 6W	1	6
24	Supervisor Office	3	PAR30 LED, 12W	1	12	No Change	No change	3	PAR30 LED, 12W	1	12
25	Assistant Office	1	4' 32w T8 Elec. bal.	2	59	No Change	Linear LED Bypass	1	4' LED T8 2000 lu. 14W	2	28
26	Assistant Office	2	60 watt Incandescent	1	60	No Change	LED Relamp	2	A19 LED, 9W	1	9
36	Bathroom	1	11w CFL Spiral Elec. bal.	1	11	No Change	No change	1	11w CFL Spiral Elec. bal.	1	11
37	Server Room	1	4' 32w T8 Elec. bal.	2	59	No Change	Linear LED Bypass	1	4' LED T8 2000 lu. 14W	2	28
38	Meeting Room	1	4' 32w T8 Elec. bal.	2	59	No Change	Linear LED Bypass	1	4' LED T8 2000 lu. 14W	2	28


Exterior Lighting Fixtures											
Existing Fixtures						Recommended	Lighting Efficiency Improvements				
Line #	Area	Qty	Present Lighting Type	Lamps /fixt	Watts /Fixt	Control Type	Measure Type	Qty	Proposed Lighting Type	Lamps /fixt	Watts /Fixt
1	Front	3	LED area light, 28W	1	28	No Change	No change	3	LED area light, 28W	1	28
2	Side	2	100 watt Incandescent	2	200	No Change	LED Relamp	2	PAR30 LED, 12W	2	24
3	Front	2	15w CFL Spiral Elec. bal.	1	15	No Change	No change	2	15w CFL Spiral Elec. bal.	1	15

Appendix B

Energy Use and Cost Summary

Energy	Units Used	BTU/unit	mmBTU	% of total	kBtu/sq.ft./year
Electricity	57,120 kwh	3,412	195	35%	30.4
Oil - No. 2	2,597 gal.	138,000	358	65%	55.8
Total			553		86.2

Cost	Energy Cost	Unit Costs	% of total	\$/sq.ft./year
Electricity	\$ 7,882	\$ 0.114 kwh	47%	\$ 1.23
Oil - No. 2	\$ 8,941	\$ 3.443 gal.	53%	\$ 1.39
Total	\$ 16,822			\$ 2.62



Energy Cost Index \$ 2.62 /sf/yr.

Energy Use Intensity 86.2 kBtu/sf/yr.

Utility Bill Data

The following pages present the energy use and cost data for your facility and establish the value of each type of energy. Electricity is measured and billed in units of kilowatt-hours (kWh) that represent the total amount of electricity used in the billing period. Electricity may also be billed based on the highest rate of use, or peak demand, that occurred during the billing period. Electric demand is billed in units of kilowatts (kW).

Other fuels may be billed in volume units (gallons, hundred cubic feet or ccf, etc.) or based on their heat content (therms, equal to 100,000 British Thermal Units). All energy types may be converted into a common unit, such as BTUs, to facilitate analysis and comparison with other facilities. One million BTUs is abbreviated as mmBtu in this report.

ELECTRICITY CONSUMPTION AND COST ANALYSIS


Town of Pound Ridge - Town House

Gross Area: 6,420 s.f.
 30,357 Btu/s.f./Yr
 \$ 1.23 /s.f.
 3.3 watts/s.f.

Utility: NYSEG
 Account # ends w/ -162
 Rate: SC
 Meter Charge: \$ 33.00 / month
 Demand Charge: \$ 10.85 / kW
 Supplier:

Month Ending	Days	Usage		Electricity Charges		Total Electricity Cost	Demand Cost	Energy \$/kWh	Load Factor	Usage /day
		Energy kWh	Demand kW	Utility Cost	Supply Costs					
7/21/21	60	7,880	13.2	\$ 393	\$ 722	\$ 1,115	\$ 143	\$ 0.115	0.41	131
9/21/21	62	12,360	21.2	\$ 616	\$ 1,132	\$ 1,748	\$ 230	\$ 0.117	0.39	199
11/19/21	59	9,080	16.4	\$ 477	\$ 831	\$ 1,309	\$ 178	\$ 0.117	0.39	154
1/21/22	63	9,400	11.4	\$ 373	\$ 841	\$ 1,214	\$ 124	\$ 0.109	0.55	149
3/17/22	55	9,080	12.9	\$ 388	\$ 813	\$ 1,201	\$ 140	\$ 0.110	0.53	165
5/20/22	64	9,320	12.8	\$ 403	\$ 892	\$ 1,295	\$ 139	\$ 0.117	0.47	146
363		57,120	87.9	\$ 2,651	\$ 5,231	\$ 7,882	\$ 954	\$ 0.114	0.45	157

Annual Energy: 57,120 kWh / year \$ 7,882 /year Unit Costs
 Peak Demand: 21 kW Peak Demand \$ 10.85 \$/kW
 Average Demand: 15 kW Energy \$ 0.114 \$/kWh Incremental
 Blended \$ 0.138 \$/kWh Blended





Note:

The electric supply costs for July, September, and November were extrapolated based on data provided for January, March, and May. The rate class, meter charge, and demand charges were each estimated based on NYSEG's current tariffs.

ALL FUELS CONSUMPTION AND COST ANALYSIS

Town of Pound Ridge - Town House

Month	mmBtu Oil - No. 2	Cost Oil - No. 2
Nov-21	32	\$ 628
Dec-21	61	\$ 1,130
Jan-22	62	\$ 1,267
Feb-22	82	\$ 1,886
Mar-22	46	\$ 1,266
Apr-22	29	\$ 869
May-22	47	\$ 1,895
Total	358	\$ 8,941
\$/mmBtu	\$ 24.95	
BTU/unit	138,000	1 mmBtu = 1,000,000 Btus
kBtu/SF/Yr.	55.8	1 kBtu = 1,000 Btus



Appendix C

EEM Calculations

Interactions

The Energy Efficiency Measure calculations in this section are stand-alone measures that are not interacted with the other calculations. Each measure shows the energy savings that may be expected if it is the only measure to be implemented. If multiple measures will be implemented, energy savings will likely be lower than the calculations represent.

As an example, replacing an 80% efficient boiler with a 92% efficient boiler will reduce the amount of fuel required to heat the building. If the walls and roof are insulated such that the required heating energy is reduced by 30%, the new boiler will serve a smaller heating load, and the energy savings gained from the boiler replacement will be reduced by 30%.

CALCULATIONS FOR INTERIOR LIGHTING RETROFIT

EEM-1	Town of Pound Ridge - Town House	Type:	Units:	Unit cost:	BTU/unit
		Oil - No. 2	gal.	\$ 3.443	138,000
		Electricity	kwh	\$ 0.114	3,412
		Demand	kW	\$ 10.85	12 Months of demand savings/year
		100% of building is air conditioned			

HVAC Adjustment Factors		
Cooling	Demand	Fuel
HVACc	HVACd	HVACg
16.00%	20.00%	-2.10%

Existing Interior Lighting Systems		Recommended Lighting Controls				Recommended Interior Lighting Efficiency Improvements								Energy & Demand Calculations												
Area	Qty	Present Lighting Type	Lamps /fixt	Watts /fixt	Control Type	% Reduction	Present Hrs./yr.	Proposed Hrs./yr.	# Controls required	Measure Type	Qty	Proposed Lighting Type	Lamps /fixt	Reflect or ?	Watts /Fixt	Project Cost	Annual Savings	kWh/yr. Savings	Payback (Years)	Present kW	Proposed kW	kW Saved	Present kwh/year	Proposed kwh/year	Controls kwh/year	Efficiency kwh/year
Basement	6	4' 32w T8 Elec. bal.	2	59	No Change	0%	50	50	0	Linear LED Bypass	6	4' LED T8 2000 lu. 14W	2		28	\$ 338	\$ 25	9	13.4	0.4	0.2	0.2	18	8	0	9
Basement	1	100 watt Incandescent	1	100	No Change	0%	50	50	0	LED Relamp	1	A19 LED, 14W	1		14	\$ 12	\$ 12	4	1.0	0.1	0.0	0.1	5	1	0	4
Basement	1	A19 LED, 9W	1	9	No Change	0%	50	50	0	No change	1	A19 LED, 9W	1		9	\$ 0	\$ 0	0	0.0	0.0	0.0	0.0	0	0	0	0
Bldg. Dept.	5	4' 32w T8 Elec. bal.	2	59	No Change	0%	2,000	2,000	0	Linear LED Bypass	5	4' LED T8 2000 lu. 14W	2		28	\$ 282	\$ 56	310	5.1	0.3	0.1	0.2	590	280	0	310
Bldg. Dept. Vault	5	4' 32w T8 Elec. bal.	2	59	Remote Occ Sensor	75%	2,000	500	2	Linear LED Bypass	5	4' LED T8 2000 lu. 14W	2		28	\$ 762	\$ 79	520	9.6	0.3	0.1	0.2	590	70	443	78
Records Room	2	4' 32w T8 Elec. bal.	2	59	Remote Occ Sensor	50%	2,000	1,000	1	Linear LED Bypass	2	4' LED T8 2000 lu. 14W	2		28	\$ 353	\$ 29	180	12.3	0.1	0.1	0.1	236	56	118	62
Tax Office	4	4' 32w T8 Elec. bal.	2	59	No Change	0%	500	500	0	Linear LED Bypass	4	4' LED T8 2000 lu. 14W	2		28	\$ 226	\$ 23	62	9.7	0.2	0.1	0.1	118	56	0	62
Rear Hallway	4	4' 32w T8 Elec. bal.	2	59	No Change	0%	2,000	2,000	0	Linear LED Bypass	4	4' LED T8 2000 lu. 14W	2		28	\$ 226	\$ 44	248	5.1	0.2	0.1	0.1	472	224	0	248
Hallway	2	60 watt Incandescent	1	60	No Change	0%	2,000	2,000	0	No change	2	A19 LED, 9W	1		9	\$ 7	\$ 37	204	0.2	0.1	0.0	0.1	240	36	0	204
Hallway	1	4' 32w T8 Elec. bal.	2	59	No Change	0%	2,000	2,000	0	Linear LED Bypass	2	4' LED T8 2000 lu. 14W	2		28	\$ 56	\$ 11	62	5.1	0.1	0.0	0.0	118	56	0	62
Court Office	3	4' 32w T8 Elec. bal.	2	59	Remote Occ Sensor	25%	2,000	1,500	1	Linear LED Bypass	3	4' LED T8 2000 lu. 14W	2		28	\$ 409	\$ 38	228	10.7	0.2	0.1	0.1	354	126	89	140
Kitchen	2	4' 32w T8 Elec. bal.	2	59	Remote Occ Sensor	75%	2,000	500	1	Linear LED Bypass	2	4' LED T8 2000 lu. 14W	2		28	\$ 353	\$ 32	208	11.1	0.1	0.1	0.1	236	28	177	31
Side Hallway	3	75 watt Incandescent	1	75	No Change	0%	2,000	2,000	1	LED Relamp	3	A19 LED, 9W	1		9	\$ 11	\$ 71	396	0.2	0.2	0.0	0.2	450	54	0	396
Dining Room	1	25 watt Incandescent	8	200	No Change	0%	500	500	0	LED Relamp	1	A15 LED, 5W	8		40	\$ 58	\$ 30	80	1.9	0.2	0.0	0.2	100	20	0	80
Dining Room	8	PAR30 LED, 12W	1	12	No Change	0%	500	500	0	No change	8	PAR30 LED, 12W	1		12	\$ 0	\$ 0	0	0.0	0.1	0.1	0.0	48	48	0	0
Dining Room	6	40 watt Incandescent	1	40	No Change	0%	10	10	0	LED Relamp	6	A15 LED, 6W	1		6	\$ 14	\$ 27	2	0.5	0.2	0.0	0.2	2	0	0	2
Town Clerk	6	4' 32w T8 Elec. bal.	2	59	Remote Occ Sensor	25%	2,000	1,500	1	Linear LED Bypass	6	4' LED T8 2000 lu. 14W	2		28	\$ 578	\$ 76	456	7.6	0.4	0.2	0.2	708	252	177	279
Clerk Office	3	4' 32w T8 Elec. bal.	2	59	No Change	0%	500	500	0	Linear LED Bypass	3	4' LED T8 2000 lu. 14W	2		28	\$ 169	\$ 17	47	9.7	0.2	0.1	0.1	89	42	0	47
Reception	1	25 watt Incandescent	3	75	No Change	0%	2,000	2,000	0	LED Relamp	1	A15 LED, 5W	3		15	\$ 22	\$ 21	120	1.0	0.1	0.0	0.1	150	30	0	120
Reception	2	40 watt Incandescent	1	40	No Change	0%	2,000	2,000	0	LED Relamp	2	A15 LED, 6W	1		6	\$ 5	\$ 24	136	0.2	0.1	0.0	0.1	160	24	0	136
Courtroom	11	PAR30 LED, 12W	1	12	No Change	0%	500	500	0	No change	11	PAR30 LED, 12W	1		12	\$ 0	\$ 0	0	0.0	0.1	0.1	0.0	66	66	0	0
Supervisor Office	3	100 watt Incandescent	1	100	No Change	0%	1,000	1,000	0	LED Relamp	3	A19 LED, 14W	1		14	\$ 36	\$ 63	258	0.6	0.3	0.0	0.3	300	42	0	258
Supervisor Office	4	40 watt Incandescent	1	40	No Change	0%	1,000	1,000	0	LED Relamp	4	A15 LED, 6W	1		6	\$ 10	\$ 33	136	0.3	0.2	0.0	0.1	160	24	0	136
Supervisor Office	3	PAR30 LED, 12W	1	12	No Change	0%	1,000	1,000	0	No change	3	PAR30 LED, 12W	1		12	\$ 0	\$ 0	0	0.0	0.0	0.0	0.0	36	36	0	0
Assistant Office	1	4' 32w T8 Elec. bal.	2	59	No Change	0%	2,000	2,000	0	Linear LED Bypass	1	4' LED T8 2000 lu. 14W	2		28	\$ 56	\$ 11	62	5.1	0.1	0.0	0.0	118	56	0	62
Assistant Office	2	60 watt Incandescent	1	60	No Change	0%	2,000	2,000	0	LED Relamp	2	A19 LED, 9W	1		9	\$ 7	\$ 37	204	0.2	0.1	0.0	0.1	240	36	0	204
2nd Floor Hallway	3	60 watt Incandescent	2	120	No Change	0%	2,000	2,000	0	LED Relamp	3	A19 LED, 9W	2		18	\$ 22	\$ 110	612	0.2	0.4	0.1	0.3	720	108	0	612
Printer Room	2	60 watt Incandescent	1	60	No Change	0%	50	50	0	LED Relamp	2	A19 LED, 9W	1		9	\$ 7	\$ 14	5	0.5	0.1	0.0	0.1	6	1	0	5
Grants Office	1	4' 32w T8 Elec. bal.	2	59	No Change	0%	2,000	2,000	0	Linear LED Bypass	1	4' LED T8 2000 lu. 14W	2		28	\$ 56	\$ 11	62	5.1	0.1	0.0	0.0	118	56	0	62
Grants Office	2	60 watt Incandescent	1	60	No Change	0%	2,000	2,000	0	LED Relamp	2	A19 LED, 9W	1		9	\$ 7	\$ 37	204	0.2	0.1	0.0	0.1	240	36	0	204
Rec. Dept.	5	4' 32w T8 Elec. bal.	2	59	No Change	0%	2,000	2,000	0	Linear LED Bypass	5	4' LED T8 2000 lu. 14W	2		28	\$ 282	\$ 56	310	5.1	0.3	0.1	0.2	590	280	0	310
Finance Dept.	2	4' 32w T8 Elec. bal.	4	112	No Change	0%	2,000	2,000	0	Linear LED Bypass	2	4' LED T8 2000 lu. 14W	4		56	\$ 166	\$ 40	224	4.1	0.2	0.1	0.1	448	224	0	224
Assessor's Office	3	4' 32w T8 Elec. bal.	2	59	No Change	0%	2,000	2,000	0	Linear LED Bypass	3	4' LED T8 2000 lu. 14W	2		28	\$ 169	\$ 33	186	5.1	0.2	0.1	0.1	354	168	0	186
Assessor's Vault	3	4' 32w T8 Elec. bal.	2	59	Remote Occ Sensor	75%	2,000	500	1	Linear LED Bypass	3	4' LED T8 2000 lu. 14W	2		28	\$ 409	\$ 48	312	8.6	0.2	0.1	0.1	354	42	266	47
2nd Floor Hallway	1	4' 32w T8 Elec. bal.	2	59	Remote Occ Sensor	75%	2,000	500	1	Linear LED Bypass	1	4' LED T8 2000 lu. 14W	2		28	\$ 296	\$ 16	104	18.7	0.1	0.0	0.0	118	14	89	16
Bathroom	1	11w CFL Spiral Elec. bal	1	11	No Change	0%	250	250	0	No change	1	11w CFL Spiral Elec. bal	1		11	\$ 0	\$ 0	0	0.0	0.0	0.0	0.0	3	3	0	0
Server Room	1	4' 32w T8 Elec. bal.	2	59	No Change	0%	50	50	0	Linear LED Bypass	1	4' LED T8 2000 lu. 14W	2		28	\$ 56	\$ 4	2	13.4	0.1	0.0	0.0	3	1	0	2
Meeting Room	1	4' 32w T8 Elec. bal.	2	59	No Change	0%	250	250	0	Linear LED Bypass	1	4' LED T8 2000 lu. 14W	2		28	\$ 56	\$ 5	8	11.5	0.1	0.0	0.0	15	7	0	8

Note: bal. = ballast, EE = energy efficient, STD = standard efficiency, mag. = magnetic, Elec. = electronic, CFL = compact fluorescent lamp

SUMMARY OF SAVINGS BY MEASURE TYPE:									
Measure Type	Qty.	Controls kwh/year	Efficiency kwh/year	kW Savings	Project Cost	Electric Savings	Payback (Years)	Measure Description	
EEM-1B	Linear LED Bypass	59	2,242	1.9	\$ 3,380	\$ 500	6.8	Replace fluorescent lamps with LED lamps; disconnect ballast	
EEM-1C	LED Relamp	30	2,157	1.8	\$ 210	\$ 478	0.4	Screw-in or Socket based LED lamps	
EEM-1L	No change	26	204	0.1	\$ 7	\$ 37	0.2		
EEM-1O	Remote Occ Sensor	8	1,357	3.8	\$ 1,920	\$ 155	12.4	Remote Mounted Occupancy Sensor	
		115	1,357	4,604		\$ 1,169			
		Gross Energy Savings		5,961	kwh				
		Net Energy Savings		6,914	kwh	4.5	-105	gal.	\$ 1,014 net
PAYBACK PERIOD:		Estimated Cost Interior Lighting:		\$ 5,518		= 5.4 year payback			
		Annual Energy Savings (kWh + kW):		\$ 1,014					

CALCULATIONS FOR EXTERIOR LIGHTING RETROFIT
EEM-2 Town of Pound Ridge - Town House

Electricity
 Unit cost: \$ 0.114 /kwh
 kW demand: \$ 10.85
 Months of demand savings: 0 months/year

Existing Exterior Lighting Systems			Recommended Lighting Controls				Recommended Exterior Lighting Efficiency Improvements										Energy & Demand Calculations										
Line #	Area	Qty	Present Lighting Type	Lamps /ftx	Watts /ftx	Control Type	% Reduction	Present Hrs./Yr.	Proposed Hrs./Yr.	# Controls required	Measure Type	Qty	Proposed Lighting Type	Lamps /ftx	Reflect or P	Watts /ftx	Project Cost	Annual Savings	kWh/Yr. Savings	Payback (Years)	Present kW	Proposed kW	kW Saved	Present kwh/year	Proposed kwh/year	Controls kwh/year	Efficiency kwh/year
1	Front	3	LED area light, 28W	1	28	No Change	0%	4,380	4,380	0	No change	3	LED area light, 28W	1		28	\$ 0	\$ 0	0	0.1	0.1	0.0	368	368	0	0	
2	Side	2	100 watt Incandescent	2	200	No Change	0%	100	100	0	LED Relamp	2	PAR30 LED, 12W	2		24	\$ 42	\$ 4	35	10.6	0.4	0.0	40	5	0	35	
3	Front	2	15w CFL Spiral Elec. ba	1	15	No Change	0%	1,000	1,000	0	No change	2	15w CFL Spiral Elec.	1		15	\$ 0	\$ 0	0	0.0	0.0	0.0	30	30	0	0	
				7	0.5 kW					0					7	0.2 kW					0.5	0.2	0.4	438	403	0	35

SUMMARY OF SAVINGS BY MEASURE TYPE:

Measure Type	Qty.	Energy Savings		kW Reduction	Project Cost	Annual Savings	Payback (Years)	Measure Description	
		Controls kwh/year	Efficiency kwh/year						
LED Relamp	2	35	35	0.4	\$ 42	\$ 4	10.6		
		35 kwh							

PAYBACK PERIOD:

Estimated Cost Exterior Lighting: \$ 42 = 10.6 year payback
 Annual Energy Savings (kWh + kW): \$ 4

CALCULATIONS TO IMPROVE TEMPERATURE CONTROL						
EEM-3 Town of Pound Ridge - Town House						
INPUT DATA:						
100% of Building to be Setback						
		Current	Proposed			
Heating T Setpoint:	Occupied	70	70	deg. F.		
	Unoccupied	70	66	deg. F.		
Cooling T Setpoint:	Occupied	74	74	deg. F.		
	Unoccupied	74	78	deg. F.		
HVAC Schedule	Occupied	40.0	40.0	Hours per week		
	Unoccupied	128.0	128.0	Hours per week		
Q internal gains:	Occupied	44,988	44,988	Btuh		
	Unoccupied	16,075	16,075	Btuh		
Q internal gains:	Schedule	40	40	Hours per week		
BLC:	Occupied	1,840	1,840	Btuh/deg. F.		
(excludes DOAS)	Unoccupied	2,165	2,165	Btuh/deg. F.		
Fuel Data		Heating	Cooling			
Type:		Oil - No. 2	Electricity	Economizer?		
Units:		gal.	kwh	0.0		
Unit cost:		\$ 3.443	\$ 0.114			
BTU/unit		138,000	3,412			
Efficiency/ COP:		78.0%	2.64	Avg. COP. EER: 9.0		
CALCULATIONS:						
100.0% of bldg. is cooled						
Current White Plains, 40 hrs./week						
Bin Mid Pt.	Occupied Hours	Unoccupied Hours	Occ Net Heat Loss BTUH	Unocc Net Heat Loss BTUH	Heating Fuel Use gal.	Cooling Energy kwh
2.5	0	17	79,245	130,081	21	0
7.5	2	41	70,043	119,255	47	0
12.5	6	84	60,840	108,429	88	0
17.5	39	179	51,638	97,602	181	0
22.5	52	421	42,436	86,776	360	0
27.5	97	332	33,233	75,949	264	0
32.5	142	509	24,031	65,123	340	0
37.5	148	553	14,828	54,297	299	0
42.5	117	661	5,626	43,470	273	0
47.5	179	685	0	32,644	208	0
52.5	136	457	(5,417)	21,817	93	82
57.5	196	615	(14,620)	10,991	63	318
62.5	214	834	(23,822)	165	1	567
67.5	220	626	(33,025)	(2,001)	0	947
72.5	225	326	(42,227)	(12,827)	0	1,521
77.5	152	182	(51,429)	(23,654)	0	1,347
82.5	100	113	(60,632)	(34,480)	0	1,107
87.5	42	29	(69,834)	(45,306)	0	472
92.5	18	6	(79,037)	(56,133)	0	196
97.5	3	2	(88,239)	(66,959)	0	44
102.5	0	0	(97,442)	(77,786)	0	0
107.5	0	0	(106,644)	(88,612)	0	0
112.5	0	0	(115,847)	(99,438)	0	0
117.5	0	0	(125,049)	(110,265)	0	0
8,760 hours					2,237	6,601
Proposed White Plains, 40 hrs./week						
Bin Mid Pt.	Occupied Hours	Unoccupied Hours	Occ Net Heat Loss BTUH	Unocc Net Heat Loss BTUH	Heating Fuel Use gal.	Cooling Energy kwh
2.5	0	17	79,245	121,420	19	0
7.5	2	41	70,043	110,594	43	0
12.5	6	84	60,840	99,768	81	0
17.5	39	179	51,638	88,941	167	0
22.5	52	421	42,436	78,115	326	0
27.5	97	332	33,233	67,288	237	0
32.5	142	509	24,031	56,462	299	0
37.5	148	553	14,828	45,635	255	0
42.5	117	661	5,626	34,809	220	0
47.5	179	685	0	23,983	153	0
52.5	136	457	(5,417)	13,156	56	82
57.5	196	615	(14,620)	2,330	13	318
62.5	214	834	(23,822)	0	0	567
67.5	220	626	(33,025)	0	0	808
72.5	225	326	(42,227)	(4,166)	0	1,207
77.5	152	182	(51,429)	(14,992)	0	1,172
82.5	100	113	(60,632)	(25,819)	0	998
87.5	42	29	(69,834)	(36,645)	0	444
92.5	18	6	(79,037)	(47,472)	0	190
97.5	3	2	(88,239)	(58,298)	0	42
102.5	0	0	(97,442)	(69,125)	0	0
107.5	0	0	(106,644)	(79,951)	0	0
112.5	0	0	(115,847)	(90,777)	0	0
117.5	0	0	(125,049)	(101,604)	0	0
8,760 hours					1,869	5,828
		Present	Proposed	Savings		
Heating		2,237	1,869	368	gal.	
Cooling		6,601	5,828	773	kwh	
Annual Energy \$				\$ 1,354		
IMPLEMENTATION COST & PAYBACK PERIOD:						
Item	Material \$/unit	Labor \$/unit	Quantity	Total		
Wi-fi thermostat	\$ 200	\$ 100	9	\$ 2,700		
				\$ 0		
				\$ 2,700		
Implementation Cost:			\$ 2,700	= 2 year payback		
Annual Energy Savings:			\$1,354			

CALCULATIONS TO INSULATE BUILDING ENVELOPE						
EEM-4		Town of Pound Ridge - Town House				
INPUT DATA:						
Surface to be insulated:	Roof	Walls				
Area:	3,589	3,497	sq ft			
Present R value:	10.0	3.7				
Revised R value	38.0	10.0				
Present U factor::	0.100	0.272	Btuh/sq ft-deg F			
Revised U factor:	0.026	0.100	Btuh/sq ft-deg F			
Present U x Area	359	950	1,309	UA Total present		
Proposed U x Area	94	350	444	UA Total proposed		
CALCULATIONS:						
	Occupied	Unoccupied	Fuel Data	Heating	Cooling	
Heating Setpoint:	70	70	Type:	Oil - No. 2	Electricity	
Cooling Setpoint:	74	74	Units:	gal.	kwh	
Q internal gains (Btuh):	44,988	16,075	Unit cost:	\$ 3.443	\$ 0.114	
BLC (Btuh/degree F):	1,840	2,165	BTU/unit	138,000	3,412	
T Balance (°F.):	45.6	62.6	Efficiency/ COP:	78.0%	263.8%	
T Balance = T Setpoint - (Q internal gains / BLC)				EER:	9.0	
Bin Mid-Pt.	Occupied Hours	Unoccupied Hours	Change in Occupied Heat Loss	Change in Unoccupied Heat Loss	Heating Savings gal.	Cooling Savings kwh
2.5	0	17	58,393	58,393	9	0
7.5	2	41	54,068	54,068	22	0
12.5	6	84	49,742	49,742	42	0
17.5	39	179	45,417	45,417	92	0
22.5	52	421	41,092	41,092	181	0
27.5	97	332	36,766	36,766	147	0
32.5	142	509	32,441	32,441	196	0
37.5	148	553	28,115	28,115	183	0
42.5	117	661	23,790	23,790	172	0
47.5	179	685	0	19,464	124	0
52.5	136	457	0	15,139	64	0
57.5	196	615	0	10,814	62	0
62.5	214	834	0	6,488	50	0
67.5	220	626	0	0	0	0
72.5	225	326	0	0	0	0
77.5	152	182	(3,028)	(3,028)	0	112
82.5	100	113	(7,353)	(7,353)	0	174
87.5	42	29	(11,679)	(11,679)	0	92
92.5	18	6	(16,004)	(16,004)	0	43
97.5	3	2	(20,329)	(20,329)	0	11
102.5	0	0	(24,655)	(24,655)	0	0
107.5	0	0	(28,980)	(28,980)	0	0
112.5	0	0	(33,306)	(33,306)	0	0
117.5	0	0	(37,631)	(37,631)	0	0
8,760 hours			Energy Savings:		1,343	432
					\$ 4,623	\$ 49
IMPLEMENTATION COST & PAYBACK PERIOD:						
Material & Labor						
	Item	(\$ / sq ft)	Quantity	Total		
	Roof	\$ 5.00	3,589	\$ 17,944		
	Walls	\$ 10.00	3,497	\$ 34,974		
		\$ 0.00	7,086	\$ 0		
Implementation Cost:			\$ 52,918	= 11.3 year payback		
Annual Energy Savings:			\$ 4,673			

CALCULATIONS TO INSTALL DOUBLE GLAZING

EEM-5	Town of Pound Ridge - Town House			Type:	Oil - No. 2
				Units:	gal.
				Unit cost:	\$ 3.443 /gal.
				Heat Content of Fuel	138,000 Btu/gal.
				Combustion Efficiency:	78%

DATA:

	Occupied	Unoccupied	
T Setpoint:	70	70	degrees F
Q internal gains:	44,988	16,075	Btuh
BLC:	1,840	2,165	Btuh/degree F
T Balance:	45.6	62.6	degrees F
T Balance = T Setpoint - (Q internal gains / BLC)			

Glazing Information

	Glazing 1		Glazing 2	
Present Conditions	Double glazed windows		Single glazed windows	
Present Area:	96	sq ft	409	sq ft
U factor:	0.50	Btuh/sq ft-deg F	1.11	Btuh/sq ft-deg F
Crack Length:	112	feet	477	feet
Present Infiltration:	10	cfh	20	cfh
Proposed Condition	Double glazed casement windows		Double glazed casement windows	
Proposed Area:	96	sq ft	409	sq ft
New U factor:	0.50	Btuh/sq ft-deg F	0.33	Btuh/sq ft-deg F
New Crack Length:	112	feet	477	feet
Proposed Infiltration:	10	cfh	10	cfh

Bin Data for White Plains, 40 hrs./week

	T Setpoint	T Balance	Accum Hours	Average O.A. Temp below T Balance	Temp Difference (T Set- Avg OAT)
Occupied	70	45.6	603	32.7	37.3
Unoccupied	70	62.6	5,388	43.2	26.8

CALCULATIONS:

Conduction Savings = (AreaPr x Upr) - (AreaRev x Urev + AreaInfill x Uinfill) x Accum Hours x Temp Diffe

Infiltration Savings = 1/2 x 0.018 x {(LengthPr x lpr) - (Length Rev x lrev)} x Accum Hours x Temp Differen

Energy Cost Savings = (Energy Savings / Conversion Factor) x (Unit cost / Efficiency)

	Conduction Savings (Btu/year)	Infiltration Savings (Btu/year)	Total Savings (Btu/year)	Total Annual Fuel Savings (gal./year)	Energy Cost Savings (\$/year)
Winter					
Occupied	7,169,000	964,000	8,133,000	76	\$ 260
Unoccupied	46,162,000	6,205,000	52,367,000	486	\$ 1,675
Annual Savings:	53,331,000	7,169,000	60,500,000	562	\$ 1,935

IMPLEMENTATION COST & PAYBACK PERIOD:

Item	Material & Labor \$ / sq. ft.	Quantity	Total
		0	\$ 0
	\$ 90	409	\$ 36,774
Implementation Cost:			\$ 36,774
Annual Energy Savings:			\$ 1,935

= 19 year payback

CALCULATIONS TO INSTALL DUCT INSULATION					
EEM-6 Town of Pound Ridge - Town House					
Input					
	Type	Units	Unit cost	BTU/Unit	Efficiency
	Electricity	kwh	\$ 0.114	3,412	266%
Present Annual Cooling Consumption:		6,955	kwh/ year		
Example Ducts					
	Duct length 1:	10	feet		
	Duct perimeter 1:	48	inches		
	Duct length 2:	20	feet		
	Duct perimeter 2:	48	inches		
	Duct temperature:	55	F		
	Ambient temperature:	85	F		
	AC EFLH	580	hours per year		
	Hours per year duct is cool:	638	hours per year		
	Proposed insulation thickness	2	inches		
Calculations					
Furnace run time = heating fuel use / furnace input capacity					
Hours per year duct is hot = Furnace run time * 110%					
Heat Loss = Heat Loss Factor * (Duct Temp - Ambient Temp) * Duct Area * Hours Per Year Duct Is Hot					
Energy Savings = Existing Heat Loss - Proposed Heat Loss					
Energy Cost Savings = (Energy Savings / Conversion Factor) x (Unit cost / Efficiency)					
Natural convection heat transfer coefficient:				0.90 Btu/hr/SF/F	
Assumes fiberglass insulation, k =.35 Btu-in/hr/F/ft2					
Duct area		120 square feet			
Existing heat loss factor		0.90	Btuh/SF/°F	R-value:	1.1
Existing heat loss		-2,065,717	Btu per year		
Proposed heat loss factor		0.15	Btuh/SF/°F	R-value:	6.8
Proposed heat loss		-336,280	Btu per year		
Energy savings		1,729,438	Btu per year		
Energy savings		190	kwhs		
Energy cost savings		\$22			
Implementation Cost and Payback Period					
			Material & Labor		
Item		(\$ / sq ft)	Quantity	Total	
2" fiberglass duct insulation		\$10.00	120	\$1,200	
			Implementation Cost:		\$1,200
Cost		\$1,200	=	55.3 years	
Annual Savings		\$22			

CALCULATIONS TO INSULATE HEATING AND DOMESTIC HOT WATER PIPES

EEM-7 Town of Pound Ridge - Town House

Input Data

Fuel Information		Type:	Units:	Unit cost:	BTU/unit	Efficiency
Heating System		Oil - No. 2	gal.	\$ 3.443	138,000	78%
DHW System		Oil - No. 2	gal.	\$ 3.443	138,000	78%
		Type #1	Type #2	Type #3		
Fluid		Hot Water	DHW	DHW		
Pipe Material		Dull Copper	Dull Copper	Dull Copper		
O.D., inches (d)		2.00	0.50	1.00		
Total Length, ft		10	25	10		
Fluid Temperature Inside Pipe, °F (Ts)		160	123	123		
Ambient Temperature, °F (Ta)		65	65	65		
Annual Operating Hours		603	8,760	8,760		
New Insulation Thickness, inches		2.0	0.5	1.0		
Thermal Conductivity - "k" (Btu-in/hr-sq ft-°F)		0.260	0.250	0.250		
Heat Loss - Bare Pipe						
C factor		1.016	1.016	1.016		
emissivity based on pipe material		0.44	0.44	0.44		
Outside Radius Pipe, inches (Ri)		1.00	0.25	0.50		
h convection, Btu/hr - s.f. pipe surface area - °F		1.26	1.51	1.31		
h radiation, Btu/hr - s.f. pipe surface area - °F		0.57	0.51	0.51		
h total		1.83	2.02	1.83		
Pipe area, sq ft/lin ft of pipe		0.523	0.131	0.262		
Q bare, Btu/hr-lin ft		91	15	28		
Heat Loss - Insulated Pipe						
Outside Radius Insulation, inches (Rs)		3.00	0.75	1.50		
Q i, Btu/hr-sq ft of outer area of insulation		7.5	17.6	8.8		
Insulation Area - sq ft/lin ft of pipe		1.6	0.4	0.8		
Q insul, Btu/hr-lin ft		11.8	6.9	6.9		
Avoided Energy Loss						
Existing Loss - mmBtu/year		0.5	3.4	2.4		
Proposed Loss - mmBtu/year		0.1	1.5	0.6		
Avoided Loss - mmBtu/year		0.5	1.9	1.8		
Total Avoided Fuel Consumption						
39		Units Saved	4	17	17	
Oil - No. 2		Fuel Type	Oil - No. 2	Oil - No. 2	Oil - No. 2	
\$ 133		\$/year	\$ 15	\$ 59	\$ 58	

Formulae:

Based on ASHRAE 1993 Fundamentals Handbook pages 20.9 and 22.17

$$h \text{ convection} = C \times \left\{ \left(\frac{1}{d} \right)^{0.2} \times \left\{ \left(\frac{1}{(Ts + Ta)/2} \right)^{0.181} \right\} \times \left\{ (Ts - Ta)^{0.266} \right\} \right\}$$

$$h \text{ radiation} = \left\{ \text{emissivity} \times 0.1713 \times 10^{-8} \times \left[(Ta + 460)^4 - (Ts + 460)^4 \right] \right\} / (Ta - Ts)$$

$$Q \text{ bare} = h \text{ total} \times \text{Pipe Area} \times (Ts - Ta)$$

$$Q \text{ i} = (Ts - Ta) / \left\{ \left[Rs \times \left(\ln \left(\frac{Rs}{Ri} \right) \right) \right] / k \right\}$$

$$Q \text{ insul} = Q \text{ i} \times \text{Insul Area}$$

$$\text{Total Avoided Consumption} = (Q \text{ bare} - Q \text{ insul}) \times \text{Total length of pipe} \times \text{Annual Operating Hours}$$

Payback Period:

Implementation Cost: \$ 349 = 2.6 years payback

Annual Energy Savings: \$ 133

CALCULATIONS TO Install Motor Controls

EEM-8 Town of Pound Ridge - Town House

DATA AND CALCULATIONS:

Electricity costs:

Formulae:

$$\text{Demand kW} = (\text{Qty} \times \text{HP} \times 0.746 \text{ kW/HP} \times \% \text{ Load}) / \% \text{ Efficiency}$$

$$\text{Annual kWh} = \text{Demand kW} \times \text{Annual Hours}$$

$$\text{Demand \$ Savings} = (\text{Present kW} - \text{New kW}) \times \text{months of demand} \times \text{Monthly demand charge}$$

$$\text{kWh \$ Savings} = (\text{Present kWh} - \text{New kWh}) \times \text{Cost per kWh}$$

kWh: \$ 0.114 per kWh
Demand: \$ 10.85 per kW

#	Description	Motor			Motor Efficiency		Annual Motor Run Hours		Months of Demand
		Nominal HP	Qty	Loading vs. Nom.	Present	New	Existing	New	Savings
1	CHW/HHW Pump	1/3	1	75%	68.0%	68.0%	4,380	2,190	0
2	CHW/HHW Pump	1/2	1	75%	68.0%	70.0%	4,380	2,190	0
3									0
4									0
5									0
6									0

#	Description	Total	Demand kW		Annual kWh		Motor Type	\$ Savings Total	Cost \$
		BHP/	Present	New	Present	New			
1	CHW/HHW Pump	0.2	0.3	0.3	1,189	595		\$ 68	
2	CHW/HHW Pump	0.4	0.4	0.4	1,802	875		\$ 106	
3									
4									
5									
6									
		0.6	0.7	0.7	2,991	1,470		\$ 173	\$ 0

ODP = open drip-proof

Peak KW Demand Savings: 0.0 kW

TEFC = totally enclosed fan-cooled

Annual KW Demand Savings: 0.0 kW

Annual kWh Savings: 1,521 kWh

Total: \$ 173

IMPLEMENTATION COST AND PAYBACK PERIOD:

Implementation Cost	\$300	= 1.7 years payback
Annual Energy Savings	\$173	

CALCULATIONS TO REPLACE CONDENSING UNITS

EEM-9 Town of Pound Ridge - Town House

INPUT DATA

kWh: \$ 0.114 per kWh
 Demand: \$ 10.85 per kW
 months /yr. demand: 5
 Coincidence Factor CF: 0.80

Location or Area Served	Main Office	Addition		
Unit Tag	Trane	Lennox		
tons/unit	3.0	3.5		
# of Units	2	1		
Unit Type (AC or HP)	AC	AC		
EFLH cool	580	497		
Present Efficiency EER *	9.0	9.0		
Present Efficiency SEER *	10.0	10.0		
Proposed Efficiency EER **	13.0	13.0		
Proposed Efficiency SEER **	17.0	17.0		

CALCULATIONS:

			Sum
Present kwh/year Cooling	4,173	2,087	6,260
Present kwh/year Heating	-	-	-
Proposed kwh/year Cooling	2,455	1,227	3,682
Proposed kwh/year Heating	-	-	-
Efficiency ΔkWh =	1,718	859	2,578
Economizer ΔkWh =	-	-	0
Demand Savings			
Present kW (peak)	6.4	3.7	10.1
Proposed kW (peak)	4.4	2.6	7.0
ΔkW =	2.0	1.1	3.1

FORMULAE:

New York Standard Approach for Estimating Energy Savings-Residential, Multi-Family and Commercial/Industrial Measures:

$\Delta kWh \text{ eff cooling} = \text{units} \times \text{tons/unit} \times (12/\text{SEERbase-12}/\text{SEERee}) \times \text{EFLHcooling}$
 $\Delta kWh \text{ eff heating} = \text{units} \times \text{kBtuH/unit} / 3.412 \times (1/\text{COPbase-1}/\text{COPee}) \times \text{EFLHheating}$
 $\Delta kWh \text{ econ} = \text{units} \times \text{tons/unit} \times \text{kwh economizer savings per ton (from Tech Manual Appendix J)}$
 $\Delta kW = \text{units} \times \text{tons/unit} \times (12/\text{EERbase-12}/\text{EERee}) \times \text{CF}$
 $\text{EFLHcool} = \text{Annual kWhcooling}/\text{kWpeak cooling without economizer (from Appendix G)}$

* Present EER and SEER are based on 2000

** Proposed EER and SEER are based on NYSECCC (IECC-2015)

Existing Energy Consumption	6,260 kwh/yr	10.1 kW peak
Proposed Energy Consumption	3,682 kwh/yr	7.0 kW peak
Annual Energy Savings	2,578 kwh/yr	3.1 kW peak

IMPLEMENTATION COST AND PAYBACK PERIOD:

Replacement cost is estimated at \$ 2,000 per installed ton of capacity

Implementation Cost \$19,000 = 41 years payback

Annual Energy Savings \$463

CALCULATIONS TO INSTALL A MORE EFFICIENT BOILER

EEM-10 Town of Pound Ridge - Town House

INPUT DATA:

Present Annual Heating Fuel Consumption:	2,232 gal.s
% of Building Served by Boiler	86%
Boiler Fuel Use	1,918 gal.s

Fuel Data	Present	Proposed
Type:	Oil - No. 2	Oil - No. 2
Units:	gal.	gal.
Unit cost:	\$ 3.443 /gal.	\$ 3.443 /gal.
BTU/Unit	138,000 Btu/gal.	138,000 Btu/gal.

Boiler Type	Present	Proposed
Boiler Firing Rate	245 kBtuh Input	245 kBtuh Input
Combustion Efficiency	85.0%	95.0% annual avg.
Jacket Losses	3.0% of capacity	1.0% of capacity
Boiler Capacity	201 kBtuh Output	230 kBtuh Output
Off-cycle Flue Losses	4.0% of capacity	0.5% of capacity
Boiler is hot when OAT <	65 °F.	65 °F.
Hours/ Yr. Unit is Hot	5,052 hrs.	5,052 hrs.
Off-Cycle Hours/Year	3,972 hrs.	4,303 hrs.
Standby Losses	30 MMBtu	12 MMBtu
Off-Cycle Flue Losses	32 MMBtu	5 MMBtu
Useful Heat Output	163 MMBtu	163 MMBtu

CALCULATIONS:

Off-Cycle Flue Losses = Boiler kBtuh Output x 1000 x % Off-Cycle Flue Losses x Hrs Off-Cycle per Year / 1,000,000

Jacket Losses = Boiler kBtuh Output x 1000 x % Jacket Losses x Hrs Hot per Year / 1,000,000

Useful Heat Output = Htg Fuel Use x BTU per Unit x Present Efficiency / 1,000,000 - Off Cycle Losses - Jacket Losses

Proposed Annual Fuel Consumption =

(Proposed Standby Losses + Useful Heat Output) / Proposed Efficiency x 1,000,000 / BTU per Unit

	Annual Fuel Consumption	Annual Cost
Present:	1,918 gal.	\$ 6,603
Proposed:	1,367 gal.	\$ 4,706
Annual Savings:	551 gal.	\$ 1,897

IMPLEMENTATION COST & PAYBACK PERIOD:

Item	Quantity	Material	Labor	Total
New Boiler	1	\$ 12,500	\$ 2,500	\$ 15,000
	0	\$ 0	\$ 0	\$ 0
Totals:				\$ 15,000

Implementation Cost	\$ 15,000	= 7.9 year payback
Annual Energy Savings	\$ 1,897	

CALCULATIONS TO INSTALL A TANKLESS WATER HEATER				
BE-1	Town of Pound Ridge - Town House			
INPUT DATA:				
		<u>Present Fuel</u>		<u>Proposed Fuel</u>
Fuel:		Oil - No. 2		Electricity
Units:		gal.		kwh
Fuel Cost:		\$ 3.44	per gal.	\$ 0.11 per kwh
BTU / unit:		138,000	Btu per gal.	3,412 Btu per kwh
kW Demand cost:		\$ 0.00	per kW	\$ 10.85 per kW
Average kW demand:		0.0	kW	1.6 kW
Demand Diversity:		33%		90%
Net kW Demand Savings:		-	kW per month	1.5 kW per month
Months of demand:		12	per year	12 per year
Annual DHW Consumption:				
		<u>Present</u>		<u>Proposed</u>
Hot Water Usage:		2.0	Gallons/person	2.0 Gallons/person
Number of persons:		40	(estimate)	40 (estimate)
Days of Usage:		250	per year	250 per year
Hours of Usage per Day:		8	hours	8 hours
Average inlet water Temp:		57	degrees F	57 degrees F
Average hot water temp:		123	degrees F	123 degrees F
Storage Tank Losses:				
		<u>Present Tank</u>		<u>Proposed Tank</u>
Tank U factor:			Btu/SF/Hour	0.09 Btu/SF/Hour
Height of Tank:			inches	15.0 inches
Diameter of Tank:			inches	10.0 inches
			gallons/tank	3 gallons/tank
# of Tanks			Qty.	1 Qty.
Hours Tank is Hot:			Hours	8,760
Water Temperature:			Deg. F.	123
Ambient Temperature:			Deg. F.	65
Recirculation Losses:				
		0.0%	of boiler capacity =	0 BTUh
		0	hours/year	8,760 hours/year =
Boiler Jacket & Flue Losses:				
Burner Input		245,000	BTUH	8,533 BTUH
COP:		0.78		1.00 COP
Boiler Output Capacity		191,100	BTU output	8,533 BTU output
Jacket & Flue Losses:		1.5%	of boiler capacity	0.0% of boiler capacity
Boiler is Hot:		8,760	hours/year	8,760 hours/year =
CALCULATIONS:				
		<u>Present</u>		<u>Proposed</u>
Consumption Energy:		11,061,525	BTU output reqd/yr	11,061,525 BTU output reqd/yr
Tank Energy Losses:		0	BTU/year	201,500 BTU/year
Recirculation Losses:		0	BTU/year	0 BTU/year
Boiler Jacket Losses:		25,110,540	BTU/year	0 BTU/year
Output BTU/Year		36,172,065		11,263,024
Annual Fuel Consumption		336	gal.	3,301 kwh
Demand		0	billed kW /yr.	18 kW
Annual Fuel Cost		\$ 1,157		\$ 567
Annual Savings:		336	gal.	\$ 590 per year
		(3,301)	kwh	
		(18)	billed kW /yr.	

CALCULATIONS TO INSTALL CLEAN HEATING SYSTEM - AIR SOURCE HEAT PUMP						
BE-2	Town of Pound Ridge - Town House					
			<u>Fuel Information</u>			
<u>Building Information</u>	Assembly			Heating	Cooling	
Location	NYC	Climate Zone 4	Type:	Oil - No. 2	Electricity	
Portion of Building HP will serve:	100%		Units:	gal.	kwh	
Building Heating Load (BHL)	146,157	BTU/h	Unit cost:	\$ 3.443	\$ 0.114 /kwh	
Building Cooling Load (BCL)	93,386	BTU/h	BTU/unit	138,000	3,412 /kwh	
BEFLHheating	1,647	Hours	Heating Eff.	85%	\$ 10.85 /kW	
BEFLHcooling	670	Hours	CO2	22.48	1.16 lbs/unit	
Existing System						
Is baseline heating system electric?		N				
Is baseline heating system fossil fuel?		Y				
If yes, will it remain in place in the efficient case?		N				
Present Heating System	Boiler, Hot Water, Oil Fired < 300 kBTU/h					
Present Cooling System	Split System – Air Conditioner (<65 kBTU/h)					
% of Portion to be served by ASHP that is presently cooled	100%					
Proposed System						
Does proposed ASHP require supplemental resistance heat?	Y					
ASHP Type	Central Ducted					
ASHP Application	Whole (the ASHP will meet all of the heating load)					
Control Type	Integrated/Modulating					
Heating Capacity	150,000	BTU/h at 17°F	1.0 HP Sizing Ratio			
Energy Efficiency Ratio	13.1	EER _{ee}				
Seasonal Energy Efficiency Ratio	15.0	SEER				
Heating Season Performance Factor	10.0	HSPF				
Resulting system to be modeled	Scenario 1d					
	Central Ducted ASHP with Integrated/ Modulating controls sized to 100%					
Adjusted Efficiency Values	Baseline	Energy Efficient				
SEER _{baseline}	9.0	14.4	EER _{season,ee}	1.520	c	cooling offset
EER _{baseline}	9.0	13.1	EER _{ee}	0.859	d	cooling slope
COP _{season,baseline}	1.00	2.52	COP _{season,ee}	0.824	a	heating offset
FElecHeat	0.00	1.00	FElecHeat,new	0.777	b	heating slope
EFF _{baseline}	0.78	1.00	Fload,cooling			
FFuelHeat	1.00	1.00	Fload,heating			
		1.00	Fload,heating,FuelHeat			0.69 CF
		1.00	Fload,heating,ElecHeat			
					Savings	Savings
	Baseline	Energy Efficient	Savings	Units	\$	CO2 Lbs/yr.
Cooling Electric Use (kWh/yr.)	6,953	4,344	2,609	kWh		
Heating Electric Use (kWh/yr.)	0	28,017	(28,017)	kWh		
Total Electric Use (kWh/yr.)	6,953	32,361	(25,408)	kWh	(\$ 2,897)	(29,473)
Peak Demand (kW)	7.2	4.9	2.2	kW	(\$ 611)	
Fossil Fuel Energy Use (MMBTU)	309	0	309	MMBtu		
Fossil Fuel Energy Use : gal.	2,237	0	2,237	gal.	\$ 7,702	50,285
Annual Energy Costs	\$ 8,832	\$ 4,638	\$ 4,194		\$ 4,194	20,812
Estimated Project Cost	\$ 3,872	per ton =	\$ 47,160		11 year payback	

CALCULATIONS TO INSTALL CLEAN HEATING SYSTEM - GROUND SOURCE HEAT PUMP						
BE-3	Town of Pound Ridge - Town House					
			<u>Fuel Information</u>			
<u>Building Information</u>	Assembly			Heating	Cooling	
Location	NYC	Climate Zone 4	Type:	Oil - No. 2	Electricity	
Portion of Building HP will serve:	100%		Units:	gal.	kwh	
Building Heating Load (BHL)	146,157	BTU/h	Unit cost:	\$ 3.443	\$ 0.114 /kwh	
Building Cooling Load (BCL)	93,386	BTU/h	BTU/unit	138,000	3,412 /kwh	
BEFLHheating	1,647	Hours	Heating Eff.	85%	\$ 10.85 /kW	
BEFLHcooling	670	Hours	CO2	22.48	1.16 lbs/unit	
Existing System						
Is baseline heating system electric?	N					
Is baseline heating system fossil fuel?	Y					
Present Heating System	Boiler, Hot Water, Oil Fired < 300 kBTU/h					
Present Cooling System	Split System – Air Conditioner (<65 kBTU/h)					
% of Portion to be served by GSHP that is presently cooled	100%					
Proposed System						
GSHP Loop Type	Closed Loop	GLHP				
GSHP Compressor Type	Variable-Speed	0.40	Capacity Ratio			
Estimated Pump Power	45 watts per ton					
Pumping Control Strategy	Variable					
Heating Capacity	150,000	BTU	rating condition			
Energy Efficiency Ratio Full Load	17.0	EER GLHP,full	77 ° EWT			
Energy Efficiency Ratio Part Load	22.0	EER GLHP,par	68 ° EWT			
Heating COP Full Load	3.6	COP GLHP,full	32 ° EWT			
Heating COP Part Load	4.1	COP GLHP,par	41 ° EWT			
Adjusted Efficiency Values						
	Baseline	Energy Efficient				
EERseason,baseline	9.0	18.87	EERseason,ee			
EERpeak,baseline	9.0	17.0	EER GSHP, full,ee			
COPseason,baseline	1.00	3.68	COPseason,ee			
FElecHeat	0.00					
EFFbaseline	0.85	0.69	CF			
FFuelHeat	1.00					
	Baseline	Energy Efficient	Savings	Units	Savings \$	Savings CO2 Lbs/yr.
Cooling Electric Use (kWh/yr.)	6,953	3,316	3,637	kWh		
Heating Electric Use (kWh/yr.)	0	19,168	(19,168)	kWh		
Total Electric Use (kWh/yr.)	6,953	22,484	(15,531)	kWh	(\$ 1,771)	(18,016)
Peak Demand (kW)	7.2	3.8	3.4	kW	(\$ 152)	
Fossil Fuel Energy Use (MMBTU)	283	0	283	MMBtu		
Fossil Fuel Energy Use : gal.	2,053	0	2,053	gal.	\$ 7,067	46,144
Annual Energy Costs	\$ 8,535	\$ 3,390	\$ 5,145		\$ 5,145	28,128
Estimated Project Cost	\$ 11,965	per ton =	\$ 145,730		28 year payback	

Appendix D

Assumptions/Data Used to Develop Energy and Dollar Savings Figures

Building and Occupancy Information

Floor Area:	6,420 square feet	Avg. # of occupants	20	Heating Setpoint	70	Cooling Setpoint	74	% of base electricity use resulting in internal heat gains	days	100%
		nights/unoccupied	0		70		74		nights	100%
		# of computer	20							
Interior lighting, people and occupied levels of internal loads occur for			40	hours per week						
Electricity use at night is usually			40%	of the usual electricity use during day periods						
(This results in an average daytime kW that is			89%	of the peak metered kW)						

Heating System Information

	% of bldg. served	COP heat	EER	Heat kBtUH	Heating Fuel	Efficiency
Primary system: Non-Condensing Boiler	100%	0.85	9.00	245	Oil - No. 2	85.0%
Secondary:	0%					
100% of building is air conditioned		Does the cooling system have economizer?				
Describe the <u>direct outside air</u> or <u>central make-up air</u> system:		Fuel	Eff.	EER for DOAS		
		cfm outside air, running	hours / week	heat recovery efficiency		

Domestic Hot Water

DHW system energy type	Fuel	Efficiency	Is there a pump to circulate DHW?	No
Hot Water usage is	Oil - No. 2	85%	1.0 gallons per person / day for	20 persons on 250 days/year

Weather & Schedule Information:

Select nearest weather station for bin data:	WHITE PLAINS	for TRM:	NYC
Base temperature for heating degree days:	65 °F. yields	5,950 HDD base65	for TRM: Assembly
Base temperature for cooling degree days:	70 °F. yields	342 CDD base70	for TRM: AC with Gas Heat

Present Schedule for Occupied/Day HVAC setpoints

Day of week	Start	End	Hours
Sun 1	12:00 AM	12:00 AM	-
Mon 2	9:00 AM	5:00 PM	8.0
Tue 3	9:00 AM	5:00 PM	8.0
Wed 4	9:00 AM	5:00 PM	8.0
Thu 5	9:00 AM	5:00 PM	8.0
Fri 6	9:00 AM	5:00 PM	8.0
Sat 7	12:00 AM	12:00 AM	-
White Plains, 40 hrs./week			40.0
			128.0

Proposed Schedule for Occupied/Day HVAC setpoints

Day of week	Start	End	Hours
1	12:00 AM	12:00 AM	-
2	9:00 AM	5:00 PM	8.0
3	9:00 AM	5:00 PM	8.0
4	9:00 AM	5:00 PM	8.0
5	9:00 AM	5:00 PM	8.0
6	9:00 AM	5:00 PM	8.0
7	12:00 AM	12:00 AM	-
White Plains, 40 hrs./week			40.0

ESTIMATE OF BUILDING LOAD COEFFICIENT & TRUE-UP TO BILLED ENERGY USE

Town of Pound Ridge - Town House
 179 Westchester Ave.
 Pound Ridge, NY 10576

Building Information

Width (typical)	54 feet	Building Floor Area	6,420 sq. ft.
Equivalent Length	60 feet	Roof Area	3,589 sq. ft.
Number of Floors	2.0 floors	Gross Wall Area	4,086 sq. ft.
Avg. Floor to Floor Height	9 feet per floor	Building Volume	57,780 cubic feet
Roof or Ceiling rise is	6 feet in 12' run		

Estimate of Conductive Heat Loss

Surface		Area	R-value	U Factor	U x A Btuh/deg. F. w/o ventilation	% of BLC
Roof	n/a	3,589	10.0	0.100	359	17%
Walls	85.6% of GWA	3,497	3.7	0.272	950	44%
Glazing 1	2.3% of GWA	96	2.0	0.500	48	2%
Glazing 2	10.0% of GWA	409	0.9	1.111	454	21%
Doors 1	4 3x7 doors	84	2.0	0.500	42	2%
Doors 2	0 3x7 doors	0	1.7	0.588	0	0%
Total Exterior Surface Area		7,675 sq.ft.			1,853	86%

		ACH	equiv. cfm	Btuh/deg. F.	BLC (without ventilation)
Est. Infiltration Rate	Occupied	0.30	289	312	1,840 Btuh/deg. F. Occupied
Est. Infiltration Rate	Unoccupied	0.30	289	312	2,165 Btuh/deg. F. Unoccupied

		cfm	Fraction	Btuh/deg. F.	Total BLC with Ventilation
Est. Ventilation Rate	Occupied	0	100%	0	1,840 Btuh/deg. F. Occupied
Est. Ventilation Rate	Unoccupied		100%	0	2,165 Btuh/deg. F. Unoccupied

Heat Gain Estimation

Estimated Solar Gain 15% of building heat loss during occupied periods will be met by solar gains

		kW	# People	Total BTUH	Hours/wk.
Loads & People	Occupied	11.8	20	44,988	40.0
	Unoccupied	4.7	0	16,075	128.0

Heat Loss Study - continued

Town of Pound Ridge - Town House
 179 Westchester Ave.
 Pound Ridge, NY 10576

Fuel Data Heating Cooling
 Type: Oil - No. 2 Electricity Economizer?
 Units: gal. kwh 0.0
 Unit cost: \$ 3.443 \$ 0.114

		Current							
Heating T Setpoint:	Occupied	70	deg. F.	BTU/unit	138,000	3,412	Nom. Eff, COP	0.85	2.638
	Unoccupied	70	deg. F.		0.78	2.64		Avg. COP	
Cooling T Setpoint:	Occupied	74	deg. F.	Avg. Eff, COP	0.78	2.64	Avg. COP	9.0	Avg. EER
	Unoccupied	74	deg. F.						
HVAC Schedule	Occupied	40	Hrs. per week	DOAS Energy Use 0 cfm 0% heat recov. Eff. Heating 0 0 0% eff. 0.00 COP cool 0 hrs/week					
	Unoccupied	128	Hrs. per week						
Q internal gains:	Occupied	44,988	Btuh						
	Unoccupied	16,075	Btuh						
Q internal gains:	Schedule	40	Hrs. per week						
BLC:	Occupied	1,840	Btuh/deg. F.						
	Unoccupied	2,165	Btuh/deg. F.						

Current		White Plains, 40 hrs./week								
Bin Mid Pt.	Occupied Hours	Unoccupied Hours	Occ Net Heat Loss BTUH	Unocc Net Heat Loss BTUH	Heating Fuel Use gal.	Cooling Energy kwh	DOAS Hours	DOAS Heating kBtu/yr.		
2.5	0	17	79,245	130,081	21	0	0	0		
7.5	2	41	70,043	119,255	47	0	0	0		
12.5	6	84	60,840	108,429	88	0	0	0		
17.5	39	179	51,638	97,602	181	0	0	0		
22.5	52	421	42,436	86,776	360	0	0	0		
27.5	97	332	33,233	75,949	264	0	0	0		
32.5	142	509	24,031	65,123	340	0	0	0		
37.5	148	553	14,828	54,297	299	0	0	0		
42.5	117	661	5,626	43,470	273	0	0	0		
47.5	179	685	0	32,644	208	0	0	0		
52.5	136	457	(5,417)	21,817	93	82	0	0		
57.5	196	615	(14,620)	10,991	63	318	0	0		
62.5	214	834	(23,822)	165	1	567	0	0		
67.5	220	626	(33,025)	(2,001)	0	947	0	0		
72.5	225	326	(44,303)	(14,903)	0	1,648	0	0		
77.5	152	182	(54,118)	(26,342)	0	1,447	0	0		
82.5	100	113	(63,667)	(37,515)	0	1,179	0	0		
87.5	42	29	(74,877)	(50,349)	0	512	0	0		
92.5	18	6	(84,019)	(61,115)	0	209	0	0		
97.5	3	2	(93,386)	(72,106)	0	47	0	0		
102.5	0	0	(97,442)	(77,786)	0	0	0	0		
107.5	0	0	(106,644)	(88,612)	0	0	0	0		
112.5	0	0	(115,847)	(99,438)	0	0	0	0		
117.5	0	0	(125,049)	(110,265)	0	0	0	0		
8,760 hours					2,237	6,955	DOAS fuel use		0	
							DOAS cool use		0	

Cross Check Against Historic Consumption

	Historic	Calculated	Difference
Present Annual Heating Fuel Use is	308 mmBTU	309	100% of present fuel use

Appendix E

Clean Heating and Cooling Technology Overview

BENEFITS OF CLEAN HEATING AND COOLING (CHC) TECHNOLOGIES

Commercial building owners are becoming increasingly aware of how their choice of HVAC system impacts bottom line operating costs and the environment. Most conventional heating systems either burn fuel or convert electricity into heat. CHC technologies, such as heat pumps, are different because they don't generate heat. Instead, they move existing heat energy from outside into your facility, which makes them more efficient since they deliver more heat energy than the electrical energy they consume.

There are many compelling reasons to install a CHC System in commercial buildings.

CHC systems:

- Can cost less to run than a traditional fossil fuel heating system.
- Integrate well with renewable and resilient building designs
- Offer the highest efficiency and most cost-effective space conditioning for HVAC
- Offer reduced maintenance costs because the exterior equipment is buried underground
- Offers flexible design and installation with many configurations available.
- Provides superior thermal comfort for all seasons.


TYPES OF CLEAN HEATING AND COOLING (CHC) TECHNOLOGIES

What is a Ground Source Heat Pump (GSHP)?

GSHP's are self-contained electrically powered systems that provide heating and cooling more efficiently than other types of conventional HVAC systems. This increase in efficiency is obtained due to the GSHP systems coupling with the earth's relatively stable ground temperature. For example, while the temperature of the outside air may vary drastically from summer to winter, the ground temperature remains relatively stable, making it an ideal heat "source" for heating and heat "sink" for cooling.

The GSHP system utilizes an electric vapor compression refrigeration cycle to exchange energy between the building load and a ground coupled loop. When in heating mode, energy is transferred from the low temperature ground loop source to the higher temperature heat sink (the load).


The system reverses during cooling, where the energy is absorbed by the ground loop.



Source: <https://www.epa.gov/rhc/geothermal-heating-and-cooling-technologies>

What is an Air Source Heat Pump (ASHP)?


An air source heat pump works much like a refrigerator operating in reverse. Outside air is blown over a network of tubes filled with a refrigerant. This warms up the refrigerant, and it turns from a liquid into a gas. This gas passes through a compressor, which increases the pressure. Compression also adds more heat – similar to how the air hose warms up when you top up the air pressure in your tires. The compressed, hot gases pass into a heat exchanger, surrounded by cool air or water. The refrigerant transfers its heat to this cool air or water, making it warm. And this is circulated around your facility to provide heating and hot water. Meanwhile, the refrigerant condenses back into a cool liquid and starts the cycle all over again.



Source: <https://www.ways2gogreenblog.com/2017/10/18/a-brief-introduction-to-air-source-heat-pumps/>

What is a Variable Refrigerant Flow (VRF)?

VRF systems use heat pumps or heat recovery systems to provide heating and cooling for all indoor and outdoor units without the use of air ducts. With a VRF system, your building will have multiple indoor units utilized by a single outdoor condensing unit, either with a heat pump or heat recovery system. A VRF HVAC system can heat and cool different zones or rooms within a building at the same time. If the appropriate VRF system is selected, building occupants have the ability to customize the temperature settings to their personal preferences. VRF equipment can be used in conjunction with a wide range of heating and cooling products. This means that a VRF system can be scaled to meet the climate control needs.



Source: https://be-exchange.org/tech_primer/tech-primer-variable-refrigerant-flow-vrf-systems/

Appendix F

Energy Savings Summaries

Energy Efficiency Measures				GHG	Electric Savings			Fuel Savings			\$ Savings & Cost		
EEM #	Measure Status	EEM Category	EEM Description	CO2e Lbs./Yr.	kWh	kW	Electric Cost Savings	Fuel Type	Fuel MMBtu Savings	Fuel Cost Savings	Total Annual Savings	Install Costs	Simple Payback (years)
EEM-1	R	Lighting	Interior Lighting Retrofit	5,655	6,914	4.5	\$ 1,376	Oil - No. 2	(14.5)	(\$ 362)	\$ 1,014	\$ 5,518	5.4
EEM-2	R	Lighting	Exterior Lighting Retrofit	41	35	0.0	\$ 4		0.0	\$ 0	\$ 4	\$ 42	10.6
EEM-3	R	Controls	Improve Temperature Control	9,162	773	0.0	\$ 88	Oil - No. 2	50.7	\$ 1,266	\$ 1,354	\$ 2,700	2.0
EEM-4	RS	Envelope	Insulate Building Envelope	30,690	432	0.0	\$ 49	Oil - No. 2	185.3	\$ 4,623	\$ 4,673	\$ 52,918	11.3
EEM-5	RS	Envelope	Install Double Glazing	13,979	0	0.0	(\$ 206)	Oil - No. 2	85.8	\$ 2,141	\$ 1,935	\$ 36,774	19.0
EEM-6	NR	HVAC	Install Duct Insulation	221	190	0.0	\$ 22		0.0	\$ 0	\$ 22	\$ 1,200	55.3
EEM-7	R	HVAC	Insulate Heating And Domestic Hot Water Pipes	868	0	0.0	\$ 0	Oil - No. 2	5.3	\$ 133	\$ 133	\$ 349	2.6
EEM-8	R	Motors	Install Motor Controls	1,765	1,521	0.0	\$ 173		0.0	\$ 0	\$ 173	\$ 300	1.7
EEM-9	NR	HVAC	Replace Condensing Units	2,990	2,578	3.1	\$ 463		0.0	\$ 0	\$ 463	\$ 19,000	41.0
EEM-10	ME	HVAC	Install A More Efficient Boiler	12,387	0	0.0	\$ 0	Oil - No. 2	76.0	\$ 1,897	\$ 1,897	\$ 15,000	7.9
Total of Recommended Measures:				17,491	9,243	4.5	\$ 1,642		41.5	\$ 1,037	\$ 2,678	\$ 8,909	3.3

Building Electrification Measures				Savings & Cost									
EEM #	Measure Status	EEM Category	Building Electrification Measure Descriptions	CO2e Lbs./Yr.	kWh	kW	Electric Cost Savings	Fuel Type	Fuel MMBtu Savings	Fuel Cost Savings	Total Annual Savings	Install Costs	Simple Payback (years)
BE-1	R	DHW	Install A Tankless Water Heater	3,725	(3,301)	(1.5)	(\$ 567)	Oil - No. 2	46.4	\$ 1,157	\$ 590	\$ 1,000	1.7
BE-2	RME	ASHP	Install Clean Heating System - Air Source Heat Pump	20,812	(25,408)	2.2	(\$ 3,508)	Oil - No. 2	308.7	\$ 7,702	\$ 4,194	\$ 47,160	11.2
BE-3	ME	GSHP	Install Clean Heating System - Ground Source Heat Pump	28,128	(15,531)	3.4	(\$ 1,922)	Oil - No. 2	283.3	\$ 7,067	\$ 5,145	\$ 145,730	28.3
Total of Recommended Measures:				24,537	(28,709)	0.8	(\$ 4,075)	\$ 0	355.1	\$ 8,859	\$ 4,784	\$ 48,160	